


**GENERAL NOTES**

1. ALL CONCRETE WORK SHALL COMPLY WITH LATEST ACI-318 SPECIFICATIONS.
2. MANHOLE TROUGH SHALL HAVE A MINIMUM OF 2" DROP FROM ENTRANCE THROUGH EXIT.
3. FLOW CHANNEL TO BE SHAPED AS TO NOT ALLOW STANDING WATER.

 EAGLE RIVER WATER & SANITATION DISTRICT	
<b>STANDARD MANHOLE</b>	
SCALE: NONE	DATE: 01-01-09
REVISIONS: 12-31-01	
APPROVED: FOR YEAR 2009	
S-01	