


GENERAL NOTES

1. 5' DIAMETER MANHOLES SHALL BE ALLOWED FOR STRAIGHT THROUGH BARSCREENS. SLOPE TO BE 0.25' MIN.
2. 6' MANHOLES SHALL BE REQUIRED FOR 3-WAY AN/OR CHANGES OF DIRECTION. SLOPE TO BE 0.30' MIN.

SLOPE BENCH AT 5% MINIMUM

| | |
|---|----------------|
|  EAGLE RIVER WATER & SANITATION DISTRICT | |
| TYPICAL BAR SCREEN MANHOLE | |
| SCALE: NONE | DATE: 01-01-09 |
| REVISIONS: 12-31-01 | S-04 |
| APPROVED: FOR YEAR 2009 | |