



GENERAL NOTES:

1. CROSSES SHALL BE CONSIDERED ON AN INDIVIDUAL BASIS. ALL USES OF THIS APPLICATION SHALL REQUIRE PRIOR DISTRICT APPROVAL.
2. MEGALUG RESTRAINT DEVICES SHALL BE REQUIRED ON ALL CROSS APPLICATIONS
3. THRUST BLOCKS WILL NOT BE ACCEPTED AS A RESTRAINT.



 EAGLE RIVER WATER & SANITATION DISTRICT	
90° CROSS DETAIL	
SCALE: NONE	DATE: 1-1-09
LAST REVISED: 12-31-03	
APPROVED FOR YEAR 2009	
W-06	