

**RULES AND REGULATIONS
FOR
WATER AND WASTEWATER SERVICE**



**EAGLE RIVER
WATER & SANITATION
DISTRICT**

Last Approved Revision: March 1, 2025

Eagle River Water & Sanitation District service area includes:

- Water Service within the Vail Water sub-district and the Wolcott area
- Wastewater Service for all areas included within the District boundaries

Upper Eagle Regional Water Authority service area includes:

- Arrowhead Metropolitan District
- Town of Avon
- Bachelor Gulch Metropolitan District
- Beaver Creek Metropolitan District
- Berry Creek Metropolitan District
- Cordillera Metropolitan District
- Eagle-Vail Metropolitan District
- Edwards Metropolitan District
- Traer Creek Metropolitan District (Village at Avon)

TABLE OF CONTENTS

SECTION 1 - GENERAL	1
1.1 Purpose	1
1.2 Statutory Authority	1
1.3 Consolidated Rules and Regulations	1
1.4 Policy	2
1.5 Scope	2
1.6 Intent of Rules and Regulations	2
1.7 Amendment	3
1.8 Waiver, Suspension, or Modification of Rules	3
1.9 Inclusion in Contract	3
1.10 Discontinuance or Revocation of Service	3
1.11 Reinstatement of Service	3
1.12 Authority to Access Customer Property	4
1.13 Severability	4
SECTION 2 - DEFINITIONS	5
2.1 Ability to Serve Letter	5
2.2 Accommodation Unit	5
2.3 Air Gap	5
2.4 Applicant	5
2.5 Applicant Representative	5
2.6 Approved	5
2.7 Attic	6
2.8 Authorized Representative of the User	6
2.9 Auxiliary Water Supply	6
2.10 Availability of Service Letter	6
2.11 Back Pressure	7
2.12 Back Siphonage	7
2.13 Backflow	7
2.14 Backflow Prevention Assembly or "Backflow Preventer"	7
2.15 Basement	7
2.16 Billing Multiplier	7
2.17 Board, Board of Directors	8
2.18 Capital Replacement Program Charge	8
2.19 Categorical Pretreatment Standard or Categorical Standard	8
2.20 Certified Cross-Connection Control Technician	8
2.21 Charge	8
2.22 The amount that a customer pays for a specific service, and/or debt, and/or capital replacement service. Check Valve	8
2.23 Colorado Department of Health Cross-Connection Control Manual	8
2.24 Commercial Account Type	8
2.25 Connection	9
2.26 Connection Fees	9
2.27 Construction Acceptance Letter	9

2.28 Construction Plan Approval Letter.....	9
2.29 Construction Review Team (CRT).....	9
2.30 Construction Water Service.....	9
2.31 Containment.....	10
2.32 Contamination, Contaminated.....	10
2.33 Contractor.....	10
2.34 Cooking Facility.....	10
2.35 Crawl Space.....	10
2.36 Critical Level.....	10
2.37 Cross-Connection.....	11
2.38 Cross-Connection, Controlled.....	11
2.39 Customer.....	11
2.40 Customer Service Manager.....	11
2.41 Customer Relations Specialist.....	11
2.42 Debt Service Bond Charge.....	11
2.43 Defective Work.....	12
2.44 Distribution System.....	12
2.45 District.....	12
2.46 District Engineer.....	12
2.47 District Inspector.....	12
2.48 Double Check Valve Assembly (“DC” or “DCVA”).....	12
2.49 Earthwork.....	12
2.50 Efficiency Unit or Studio Unit.....	12
2.51 Electronic Drawing File.....	13
2.52 Employee Handbook.....	13
2.53 Environmental Protection Agency or EPA.....	13
2.54 Final Acceptance Letter.....	13
2.55 Flood-Level Rim.....	13
2.56 Floor Area.....	13
2.57 Garage.....	13
2.58 General Manager.....	13
2.59 GIS.....	14
2.60 GPS.....	14
2.61 Hazard, Degree of.....	14
2.62 Hazard, Health.....	14
2.63 Hazard, Plumbing.....	14
2.64 Hazard, Pollution.....	14
2.65 Hazard, System.....	15
2.66 Impact Fee.....	15
2.67 Indirect Discharge or Discharge.....	15
2.68 Individually Metered Residential Account Type.....	15
2.69 Industrial Fluids System.....	15
2.70 Interference.....	16
2.71 Irrigation-Only Account Type.....	16
2.72 Isolation.....	16
2.73 kGal.....	16

2.74 Land Use Authority (LUA)	16
2.75 Major Facility	17
2.76 May	17
2.77 Mixed-Use Account Type	17
2.78 Multi-Family Residential Account Type	17
2.79 Non-Potable Water	17
2.80 Pass Through	17
2.81 Permanently Non-Metered Account Type	18
2.82 Pollution – see Contamination	18
2.83 Plan Review Engineer	18
2.84 Potable Water	18
2.85 Preconstruction Meeting	18
2.86 Pretreatment Standard or Standards	18
2.87 Private Mains	18
2.88 Prohibited Discharge Standards or Prohibited Discharges	19
2.89 Public Use Facility	19
2.90 Reduced Pressure Principle Assembly, Reduced Pressure Zone Assembly (“RPZ”)	19
2.91 Regional Facilities	19
2.92 Regulations Administrator	19
2.93 Residential Unit	19
2.94 Rules and Regulations	20
2.95 SCADA	20
2.96 Service Charge	20
2.97 Sewer System	20
2.98 Shall	20
2.99 Significant Industrial User	20
2.100 Single Family Equivalent (SFE)	21
2.101 Slug Load or Slug	21
2.102 Spring Line	21
2.103 Stub Out	21
2.104 Submerged Inlet	21
2.105 Subsurface Utility Engineering-Required Project	21
2.106 Survey	21
2.107 Suspended Service	22
2.108 System Tampering	22
2.109 System Tampering Fine	22
2.110 Tap	22
2.111 Tie-in	22
2.112 Tiered Rate Structure	23
2.113 Turn-On and Turn-Off	24
2.114 Unauthorized Use	24
2.115 User or Industrial User	24
2.116 Vacuum	24
2.117 Vacuum Breaker, Pressure Type	24
2.118 Variance	25

2.119 Warranty Period	25
2.120 Wastewater Main.....	25
2.121 Wastewater Service Line.....	25
2.122 Wastewater Treatment Plant.....	25
2.123 Wastewater System	25
2.124 Water Main.....	26
2.125 Water Meter.....	26
2.126 Water Service Line	26
2.127 Water Supply Fixture Unit (WSFU).....	26
2.128 Water System.....	26
2.129 Water System Impact Fee (WSIF).....	26
2.130 Water Use Rate.....	27
2.131 Work.....	27
2.132 Any Other Term.....	27
SECTION 3 - OWNERSHIP AND LIABILITY	28
3.1 Liability of District	28
3.2 Compliance with Industrial Pretreatment Requirements.....	28
3.3 Ownership of Facilities	28
3.4 Water Service.....	28
3.5 Water Meter	29
3.6 Wastewater Services.....	29
3.7 Lift Stations	30
3.8 Existence of Rights-of-Way and Easements	30
3.9 Conditions of Ownership	31
3.10 Violator's Liability.....	31
SECTION 4 - AUTHORIZATION TO CONNECT TO WATER & WASTEWATER SYSTEMS	33
4.1 Service Areas.....	33
4.1.1 Service within the Eagle River Water & Sanitation District:.....	33
4.1.2 Service within the Upper Eagle Regional Water Authority:	33
4.1.3 Including Property into the Eagle River Water & Sanitation District:	33
4.2 Water Rights Dedication Requirement	34
4.2.1 Property in the Upper Eagle Regional Water Authority Service Area.....	34
4.2.2 Property in the Eagle River Water & Sanitation District Service Area	34
4.3 Ability to Serve Letter	35
4.4 Infrastructure Acceptance Process.....	35
4.5 Connection to Water and Wastewater System.....	35
4.5.1 Connections per Account.....	35
4.5.2 District Approval Required	35
4.5.3 Application	36
4.5.4 Availability of Service Letter	36
4.5.5 Meter Sizing	36
4.5.6 Connection Fees.....	36
4.5.7 Treated Water Storage Requirement.....	37
4.5.8 Water Meter Fee	37

4.5.9 Disputes	37
4.5.10 Abandonment of Service	37
4.5.11 Prepaid Impact Fees	38
4.5.12 Additional Assessment of Fees	38
4.5.13 Transfer of Connection Fees	39
4.5.14 Expansion of Pre-1987 Residential Units	39
4.5.15 Construction Water Service	40
4.5.16 Temporary Suspension of Service	40
4.5.17 Unauthorized Use	40
4.5.18 Fire Suppression Systems	40
4.5.19 Irrigation-Only Accounts	41
4.5.20 Winter Connection	41
SECTION 5 - BILLING FOR WATER AND WASTEWATER SERVICE	42
5.1 Authorization and Applicability	42
5.2 Application of this Article	42
5.3 New Accounts	42
5.4 Payment	42
5.5 Monthly Billing	42
5.6 Service Charges, Debt Service Bond Charges, Capital Replacement Program Charges and Use Rates	43
5.7 Charges Related to Turn-On and Turn-Off of Service	43
5.8 Billing Errors	43
5.9 Fees for Unauthorized Use	44
5.10 Fee for Non-Compliance	44
5.11 Collections on Delinquent Accounts	44
5.11.1 District Notices and Actions	44
5.11.2 Certification of Amounts to County Treasurer	44
SECTION 6 - USE OF THE WATER AND WASTEWATER SYSTEMS	46
6.1 District Responsibilities	46
6.2 Customer Limitations	46
6.3 Unauthorized Operation of Water and Wastewater Systems	46
6.4 Water and Wastewater Access	46
6.5 Locating District Facilities	47
6.6 Underground Locatable Facilities	47
6.7 Directional Drilling/Boring	47
6.8 Scheduling Service or Inspections	47
6.9 Use of Water System	48
6.9.1 All Water Use Metered	48
6.9.2 Water Meter	48
6.9.3 Operation of Meter Bypass	48
6.9.4 Inaccurate or Broken Water Meter	48
6.9.5 Backflow Prevention Assemblies	48
6.9.6 Turn-On/Turn-Off of Water Service	49
6.9.7 Pressure Reducing Valve	49
6.9.8 Repair of Water Service Line	49

6.9.9 Maintaining Fire Hydrant Clearances	50
6.9.10 Construction Water / Fire Hydrant Meter Assemblies	50
6.9.11 Efficient and Beneficial Water Use	51
6.9.12 No Wasteful Water Use	51
6.9.13 Irrigation and Outdoor Use Regulations-General	51
6.9.14 Irrigation Permits	51
6.9.15 Use Restrictions – Water Supply Emergencies.....	51
6.9.16 Filling of Swimming Pools	52
6.9.17 Water Features	52
6.10 Use of Wastewater System	52
6.10.1 Prohibited Discharges	52
6.10.2 Pretreatment Facilities	52
6.10.3 Repair of Wastewater Service Line	53
6.10.4 Draining of Swimming Pools and Hot Tubs	53
6.10.5 Grease Interceptor	54
6.10.6 Control Manhole	54
SECTION 7 - HEARING, SETTLEMENT AND APPEAL PROCEDURES	55
7.1 Application	55
7.2 Variance	55
7.3 Initial Complaint Resolution	55
7.4 Expedited Appeal and Settlement	56
7.5 Formal Appeal	56
7.6 Conduct of Hearing	57
7.6.1 Decision on Appeal	57
7.7 Appeal to the Board of Directors	58
7.7.1 Conduct of Board Hearing	58
7.7.2 Board Decision on Appeal	58
7.8 Notice	58
SECTION 8 - DEVELOPMENT APPROVAL PROCESS.....	59
8.1 General	59
8.2 Initiation of Development Approval Process	59
8.3 Inclusion into Eagle River Water and Sanitation District or the Service Area of the Upper Eagle Regional Water Authority	60
8.4 Water Rights Dedication Analysis	60
8.5 Determination of Sufficient System Capacity	61
8.6 Determination of Treated Water Storage Dedication	61
8.7 Conditional Capacity to Serve Letter	62
8.8 Ability to Serve Letter	62
SECTION 9 - INFRASTRUCTURE ACCEPTANCE PROCESS	64
9.1 General	64
9.2 Construction Plan Approval	64
9.2.1 Construction Plan Submittal Requirements	65
9.2.2 Determination of Corrosive Soils	67
9.2.3 Determination of High Groundwater	67

9.2.4 Major Facilities	67
9.2.5 Regional Facilities	68
9.2.6 Special Conditions	69
9.2.7 Construction Plan Approval Letter	69
9.3 Initiation of Construction	70
9.3.1 Construction Site Safety Provisions	71
9.3.2 Inspection.....	71
9.3.3 Field Maintenance Inspection Requirements	71
9.3.4 Bypass System Requirements	72
9.4 Construction Acceptance	73
9.4.1 Construction Acceptance Submittal Requirements	73
9.4.2 Warranty Period	76
9.4.3 Construction Acceptance Letter	77
9.5 Final Acceptance	77
9.5.1 Final Acceptance Submittal Requirements	78
9.5.2 Final Acceptance Letter	78
SECTION 10 - WATER DEDICATION REQUIREMENT	79
10.1 General Purpose	79
10.2 Dedication of Water Rights.....	79
10.3 Cash In Lieu of Water Rights	80
10.4 Payment of Costs	80
10.5 Applicability of Requirement.....	81
10.6 Consideration of Prior Dedications	81
SECTION 11 - WATER SUPPLY RESPONSE PLAN	82
11.1 Goals.....	82
11.2 Water Supply Emergencies	82
11.3 Response Levels.....	82
11.4 Dry Year Response	83
11.5 Resource Protection Response.....	83
11.6 Public Health and Safety Response	84

ARTICLE 1 - GENERAL

1.1 Purpose

The purpose of these consolidated Rules and Regulations is to ensure orderly and uniform administration of water and wastewater operations within the service areas of the Eagle River Water & Sanitation District and the Upper Eagle Regional Water Authority, located in Eagle County, Colorado. These administrative responsibilities are performed by the Eagle River Water & Sanitation District, by which administrative and operations personnel implement these Rules and Regulations for both the Eagle River Water & Sanitation District and the Upper Eagle Regional Water Authority.

1.2 Statutory Authority

The Eagle River Water & Sanitation District and the Upper Eagle Regional Water Authority are both quasi-municipal corporations and political subdivisions of the State of Colorado. These Rules and Regulations are specifically promulgated pursuant to and for the purposes of carrying out the objectives and purposes stated in the Special District Act and C.R.S. § 29-1-204.2, respectively.

1.3 Consolidated Rules and Regulations

These Rules and Regulations are intended to separately apply to Eagle River Water & Sanitation District and Upper Eagle Regional Water Authority; however, the parties have determined that it is efficient to consolidate these Rules and Regulations into one document. One party's amendment, modification, use, or interpretation of these Rules and Regulations shall not be binding or constitute a precedent with regard to the other party's use or interpretation of these Rules and Regulations. For the purposes of these Rules and Regulations, the term "District" includes the Eagle River Water & Sanitation District and the Upper Eagle Regional Water Authority, as applicable.

Eagle River Water & Sanitation District serves Customers owning property located within its service area. The Eagle River Water & Sanitation District serves Customers owning property located within its service area in the town of Minturn for wastewater, but not water. These Rules and Regulations shall be effective for the Eagle River Water & Sanitation District service area and all areas served under contract when approved by the Board of Directors of the District.

The Upper Eagle Regional Water Authority was formed by the following entities:

1. Arrowhead Metropolitan District;
2. Beaver Creek Metropolitan District;
3. Berry Creek Metropolitan District;

4. Eagle-Vail Metropolitan District;
5. Edwards Metropolitan District; and
6. Town of Avon

The following entities receive service through contract with the Upper Eagle Regional Water Authority:

1. Bachelor Gulch Metropolitan District;
2. Cordillera Metropolitan District; and
3. Traer Creek Metropolitan District (Village at Avon)

Each of these entities is the water provider of record for its service area and has delegated its Water Service obligations to the Upper Eagle Regional Water Authority, which in turn has contracted for administrative, operations and maintenance services from the Eagle River Water & Sanitation District. These Rules and Regulations shall be effective for Customers within the service area of each of these entities when approved by the Board of Directors of the Upper Eagle Regional Water Authority.

1.4 Policy

The Board of Directors of the District hereby declares that the Rules and Regulations hereinafter set forth serve a public purpose and are necessary to promote the health, safety, prosperity, security, and general welfare of the inhabitants of the District.

1.5 Scope

These Rules and Regulations are comprehensive regulations which govern the water and wastewater operations and functions of all Customers served by the District, and supersede all prior publications of the Rules and Regulations of the District. These Rules and Regulations do not nullify or modify any policies in effect and approved by the Board of Directors existing on the date of adoption of these Rules and Regulations or adopted thereafter.

1.6 Intent of Rules and Regulations

These Rules and Regulations are adopted respecting the exercise of the District's powers and the carrying out of its purpose; they shall be liberally construed to affect the general purposes set forth herein; and each and every part is separate and distinct from all other parts. No omission or additional material in these Rules and Regulations shall be construed as an alteration, waiver, deviation, limitation, or restriction from any grant of power, duty, or responsibility imposed or conferred upon the Board of Directors by virtue of statutes now existing. Nothing contained herein shall be construed to prejudice or affect the right of the District to secure the full benefit and protection of any law which

is now enacted or may subsequently be enacted by the Colorado General Assembly pertaining to the governmental or proprietary affairs of the District.

1.7 Amendment

The District, through its Board of Directors, shall retain the power to amend these Rules and Regulations to reflect those changes determined to be necessary by the Board of Directors. Prior public notice of amendments to these Rules and Regulations shall not be required by the Board of Directors when exercising its amendment powers.

1.8 Waiver, Suspension, or Modification of Rules

The General Manager acting on behalf of the Board of Directors shall have the sole authority to waive, suspend, or modify these Rules and Regulations. Any such waiver, suspension, or modification must be in writing authorizing the specific action. Such waiver, suspension or modification is an exception to these Rules and Regulations for the specific instance and shall not be construed as precedent for future instances. Waivers, suspensions, or modifications are not deemed an amendment of these Rules and Regulations.

1.9 Inclusion in Contract

All Customers of the District who receive water or wastewater services are bound by these Rules and Regulations as a matter of contract for which there is good and valuable consideration. These Rules and Regulations are automatically incorporated into every contract, written or oral, for service from the District whether expressly referenced or not, to the extent they are not inconsistent with the contract for service.

1.10 Discontinuance or Revocation of Service

The District reserves the right to temporarily discontinue service to any property, at any time, for any reason deemed necessary or appropriate. The District shall have the right to revoke service to any property for violations of these Rules and Regulations in accordance with the procedures set forth in these Rules and Regulations.

1.11 Reinstatement of Service

Reinstatement of service to a property to which service has been discontinued or revoked shall not occur until all charges due to the District by the Customer are paid and all other requirements for service are satisfied, as determined by the District.

1.12 Authority to Access Customer Property

Authorized representatives of the District, upon presentation of a work order and identification, must be permitted to and shall have a right to enter upon a Customer's property at reasonable times for the purposes of inspection, observation, measurement, sampling, testing, detection of leaks, Turn-On or Turn-Off of Water Service, inspection of records, and investigation of any violation of these Rules and Regulations. Failure of a Customer to permit such inspections, observations, measurements, samplings, testing, or inspection of records upon the request, in writing, of the General Manager may result in a finding that permission is being denied to avoid discovery of a violation of these Rules and Regulations. Such finding may result in the disconnection of service or other remedies as allowed under these Rules and Regulations. Refer to Article 3, Violator's Liability.

1.13 Severability

In the event any of the terms or provisions of these Rules and Regulations shall be held invalid as to any person, property, or circumstance by any court having competent jurisdiction, the remainder of these Rules and Regulations and the application and effect of their terms and provisions to such persons, property, or circumstances shall not be affected thereby.

ARTICLE 2 - DEFINITIONS

Unless the context specifically indicates otherwise, the meaning of the terms used herein shall be as follows:

2.1 Ability to Serve Letter

A letter from the District stating that it will serve a proposed use of the Water System or Wastewater System permitted by a Land Use Authority.

2.2 Accommodation Unit

One habitable room intended primarily for sleeping purposes, without a Cooking Facility, but with private access to a central corridor or the outside. Examples of an Accommodation Unit include but are not limited to a hotel room, hotel suite, hostel room, bed and breakfast room, or a lock-off unit without a Cooking Facility. An Accommodation Unit is equal to 0.35 SFE.

2.3 Air Gap

The unobstructed separation or physical break between the supply of water from the Water System and the location of use of the water by the Customer.

2.4 Applicant

Any person, association, corporation, entity, or governmental entity requesting Water or Wastewater Service for premises under its control. Applicant is responsible for compliance with the District's Infrastructure Acceptance Procedure, and for Applicant's contractor's performance of any and all Work.

2.5 Applicant Representative

The designated representative of the Applicant authorized by the Applicant to act on Applicant's behalf with respect to Water Service or Wastewater Service to be provided to Applicant and Applicant shall be bound by the acts and representations of the Applicant Representative.

2.6 Approved

Accepted by the District as meeting the applicable specification or procedures of these Rules and Regulations.

2.7 Attic

The part of a structure that is immediately below and wholly or partly within the roof framing. An Attic that is less than five (5) feet in height shall be excluded from Floor Area calculations.

2.8 Authorized Representative of the User

If the User is a corporation:

1. The president, secretary, treasurer, or a vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation; or
2. The manager of one or more manufacturing, production, or operation facilities employing more than two hundred fifty (250) persons or having gross annual sales or expenditures exceeding twenty-five (25) million dollars (in second-quarter, 1980 dollars), if authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

If the User is a partnership or sole proprietorship: a general partner or proprietor, respectively.

If the User is a federal, state, or local governmental facility: a director or highest official appointed or designated to oversee the operation and performance of the activities of the government facility, or their designee.

The individuals described above may designate another authorized representative if the authorization is in writing, the authorization specifies the individual or position responsible for the overall operation of the facility from which the discharge originates or having overall responsibility for environmental matters for the company, and the written authorization is submitted to the District.

2.9 Auxiliary Water Supply

Any water supply on or available to the premises other than that which is provided directly from the Water System. Auxiliary water supplies may include, but are not limited to, water from the District's Drinking Water System over which the District does not control the water quality, such as where an Air Gap has been made, or from any other water supply or natural source(s) such as a well, spring, river, stream, pond, or lake.

2.10 Availability of Service Letter

A letter required by a land use Authority for a building permit application to demonstrate that water and wastewater mains are within the vicinity of the property and that water

service and wastewater service will be provided to the property upon payment of impact fees.

2.11 Back Pressure

Backflow caused by a pump, elevated tank, boiler, or "head" in pipe, or any means that creates greater pressure within a piping system than that which exists within the Water System.

2.12 Back Siphonage

The actual or potential reverse flow of water or contaminants into the Water System caused by negative or sub-atmospheric pressure in the Water System.

2.13 Backflow

The actual or potential undesirable reversal of the direction of flow of the water or the mixture of water and other liquids, gases, or other substances into the pipes of the Water System from any source or sources caused by Back Pressure and/or Back Siphonage.

2.14 Backflow Prevention Assembly or "Backflow Preventer"

An assembly designed to prevent backflow created by Back Pressure, Back Siphonage or Back Pressure and Back Siphonage acting together.

2.15 Basement

The lowest area within a structure, either partially or entirely below finished grade with a finished or concrete floor, with a ceiling over five (5) feet high and which may be unfinished.

2.16 Billing Multiplier

A multiplier applied to the Customer's Service Charge, Debt Service Bond Charges, and Capital Replacement Charge that is proportionate to the Customer's demand on the water system as determined by square footage for Individually Metered Residential Account Types, by meter size based on fixture count for Multi-Family Residential, Mixed-Use, and Commercial Account Types, and by irrigated acreage for Irrigation-Only Account Types.

2.17 Board, Board of Directors

Refers to the Board of Directors of the District or the Upper Eagle Regional Water Authority, whose members may be elected or appointed, having responsibility for policy and management oversight of the District's Water System and/or Wastewater System.

2.18 Capital Replacement Program Charge

A charge assessed to fund capital assets that have a recurring replacement schedule.

2.19 Categorical Pretreatment Standard or Categorical Standard

Any regulation containing pollutant discharge limits promulgated by EPA in accordance with Sections 307(b) and (c) of the Act (33 U.S.C. § 1317) which apply to a specific category of users, and which appear in 40 CFR Chapter I, Subchapter N, Parts 405-471.

2.20 Certified Cross-Connection Control Technician

A person certified to test and/or repair Backflow Prevention Assemblies as such by the American Backflow Prevention Association (ABPA) or American Society of Sanitary Engineering (ASSE).

2.21 Charge**2.22 The amount that a customer pays for a specific service, and/or debt, and/or capital replacement service. Check Valve**

A self-closing assembly designed to permit the flow of fluids in only one direction. A single Check Valve is not an Approved Backflow Prevention Assembly.

2.23 Colorado Department of Health Cross-Connection Control Manual

A manual that has been published by the State addressing Cross-Connection control practices.

2.24 Commercial Account Type

An account type for any structure or facility that is used to engage in: business, commerce, manufacturing, marketing, and/or sale of products and services of any kind. This may also be referred to as an industrial unit. The billing multiplier for a Commercial Account Type is based on meter size.

2.25 Connection

The existence of a continuous pipe or conduit from a Customer's structure or place of water use and the Water or Wastewater System.

A Connection shall be deemed to have been made to either the Water or Wastewater System when no Air Gap exists between the Customer's structure or place of use and the District's Water Main or Wastewater Main, respectively. In the case of a new or expanded use added to an existing Connection, the new connection is deemed to be made when the new or expanded use first occurs. Refer to Article 4, Connection to Water and Wastewater System.

2.26 Connection Fees

Any applicable fees and rates due to the District at the time of Connection, and may include, but are not limited to: Impact Fees, Water System Impact Fees, Turn-On and Turn-Off fees, and any interest or penalties.

2.27 Construction Acceptance Letter

Evidence of the District's determination that construction is complete, and that the Applicant has fully complied with all construction acceptance procedures and requirements. The Construction Acceptance Letter grants the Applicant permission to apply for service connection to the District's Water and/or Wastewater Systems.

2.28 Construction Plan Approval Letter

Evidence of the District's approval of Applicant's construction plans, and specifications.

2.29 Construction Review Team (CRT)

A group of District staff appointed by the General Manager authorized to perform duties as described in these Rules and Regulations.

2.30 Construction Water Service

Water Service to a property prior to the payment of Impact Fees by a Customer. Refer to Article 4, Construction Water Service. Impact fees must be paid prior to turning on permanent Water Service.

2.31 Containment

Installation of an Approved Backflow Prevention Assembly or method, on the Water Service Line serving any premises, location, facility or area. Protection by Containment shall be used when the potential exists for the Water System to become contaminated or polluted by substances used or stored within a building or premises.

2.32 Contamination, Contaminated

The degradation of the water quality relative to state and federal standards to which the District's water supply is regulated by the Colorado Department of Public Health and Environment and the Environmental Protection Agency, or which otherwise creates a potential Hazard to the public health through the introduction of any physical, chemical, biological, or radiological substance or matter to the Water System.

2.33 Contractor

Any person, firm, or corporation licensed or permitted to perform Work and to furnish materials for such Work within the District.

2.34 Cooking Facility

An area used or designated to be used for the cooking or preparation of food within a Residential Unit which provides refrigeration capability and facilities for washing or cleaning of cooking utensils and serving dishes, and includes one or more of the following appliances: stove, counter-top burner, oven, microwave, hotplate, electrical griddle, toaster oven, or crock pot.

2.35 Crawl Space

Any area of a structure that shall have a ceiling height of less than five (5) feet, measured from the surface of the earth or floor system to the underside of the structural members of the floor directly above.

2.36 Critical Level

The Critical Level or other regulated "C/L marking" on a Backflow Prevention Assembly or Vacuum Breaker which is a point conforming to standards and established by a testing laboratory, which determines the minimum elevation above the Flood-Level Rim of the fixture, highest point of usage, or receptacle served at which the assembly may be installed. When a Backflow Prevention Assembly does not bear a Critical Level marking, the bottom of the Vacuum Breaker, combination valve, or the bottom of any such approved assembly shall constitute the Critical Level.

2.37 Cross-Connection

Any physical arrangement whereby a Potable Water supply is connected, directly or indirectly, with any other water supply system, wastewater, drain, conduit, tank, plumbing fixture, or other device which contains, or may contain, contaminated water, sewage, or other waste, liquid or gas of unknown or unsafe quality which may be capable of contaminating the Water System as a result of Backflow. Bypass arrangements, jumper connections, removable spools, swivel or changeover assemblies, four-way valve connections, and other temporary or permanent assemblies through which, or because of which, Backflow could occur are included in the definition of Cross-Connection.

2.38 Cross-Connection, Controlled

Having an accepted Cross-Connection control assembly properly installed and maintained. This assembly shall continuously provide Cross-Connection protection commensurate with the degree of hazard.

2.39 Customer

Any person or entity owning property within the District and authorized to connect to and use the District's Water or Wastewater System.

2.40 Customer Service Manager

An employee of the District authorized to perform duties as described in these Rules and Regulations.

2.41 Customer Relations Specialist

An employee of the District authorized to perform duties as described in these Rules and Regulations.

2.42 Debt Service Bond Charge

A billing charge, specific to the location of a Customer's Water or Wastewater System use, that when applied to the Customer account's Billing Multiplier, determines a portion or total of the Charge due from the Customer to the District. Revenues collected by the District from Debt Service Bond Charge(s) are used by the District specifically to pay debt service on borrowed funds for major water and wastewater capital improvements.

2.43 Defective Work

An installation or Work that is unsatisfactory, faulty, deficient, or does not meet the requirements of any inspection, test, or approval, or an installation or Work that has been damaged prior to acceptance by the District.

2.44 Distribution System

District Water Mains including valves, fire hydrants, Connections, meters, service pipes from the Water Main to the curb stop or property line/easement (whichever is closer to the Water Main), and associated appurtenances, property, easements, and equipment used or to be used in distributing water to customers.

2.45 District

The Eagle River Water & Sanitation District or the Upper Eagle Regional Water Authority, as applicable.

2.46 District Engineer

Any person or firm that has been authorized by the District to perform engineering services for the District.

2.47 District Inspector

Any person or firm that has been authorized by the District to inspect the Water and Wastewater Systems, and the property of Customers and Industrial Users to ensure compliance with these Rules and Regulations.

2.48 Double Check Valve Assembly (“DC” or “DCVA”)

An assembly of two independently operating Approved Check Valves between two tightly closing (resilient seated) shut-off valves, plus four properly located test cocks for the testing of each Check Valve.

2.49 Earthwork

Any clearing, grubbing, grading, excavation, fill, backfill, excess excavation, bedding material, borrow material, and surface restoration required to complete the installation of water or wastewater infrastructure and services.

2.50 Efficiency Unit or Studio Unit

A Residential Unit having one room with an integral Cooking Facility and one bathroom. An Efficiency Unit is equal to 0.50 SFE.

2.51 Electronic Drawing File

An Electronic Drawing File shall be AutoCAD “.dwg” drawing format file, unless specified otherwise.

2.52 Employee Handbook

The document that contains the District’s policies and requirements for the conduct of District employees, which may be updated periodically with or without advanced notice.

2.53 Environmental Protection Agency or EPA

U.S. Environmental Protection Agency or, where appropriate, the Regional Water Management Division Director, or other duly authorized official of said agency.

2.54 Final Acceptance Letter

Evidence of the District’s acknowledgement that the Applicant has complied with all Final Acceptance requirements, including any repairs and/or replacements of faulty and/or defective materials and/or installation. Issuance of the Final Acceptance Letter ends the required Warranty Period.

2.55 Flood-Level Rim

The edge of the receptacle from which liquid overflows.

2.56 Floor Area

Floor area is calculated on the gross square foot measurement within the outside walls, including unfinished areas, mechanical rooms, storage space, etc. and basements and attics over five (5’) feet high. Floor Area is used to calculate the Billing Multiplier for individually Metered Residential Account Types.

2.57 Garage

An accessory building or an accessory portion of a main building for private, residential use designed for shelter or storage of motor vehicles which are owned and operated by the occupant of the main building. Habitable spaces within garages such as, offices, bathrooms, storage, mechanical rooms or other similar uses will be counted towards the property’s Floor Area.

2.58 General Manager

The person authorized by the Board of Directors to manage, administer, and supervise the affairs of the District.

2.59 GIS

A Geographical Information System (GIS) is a digital mapping system used by the District to track its Water and Wastewater infrastructure and related geospatial data.

2.60 GPS

A Global Positioning System is an electronic device used to identify locations within the District.

2.61 Hazard, Degree of

The term is derived from an evaluation of the potential risk to public health and the adverse effect of the Hazard upon the Potable Water System as determined by the State of Colorado.

2.62 Hazard, Health

Any condition, assembly, or practice in the Water System or Services which creates, in the judgment of the District, an actual or potential danger to the health or well-being of a water consumer. An example of a Health Hazard is a structural defect, including Cross-Connections, in the Water System, or a direct connection of the Water System to a Wastewater System or any source of water or Contamination. The presence of any potential for a Health Hazard requires the installation of an Approved Backflow Prevention Assembly.

2.63 Hazard, Plumbing

A type of Cross-Connection that results from a fixture, fitting or connection in the Water System or Water Service Line that has not been properly protected by an air-gap separation, or an Approved Backflow Prevention Assembly. A Plumbing Hazard is deemed to be a Health Hazard.

2.64 Hazard, Pollution

An actual or potential threat to the physical properties of the water in the Water System which would constitute a nuisance or be aesthetically objectionable or cause damage to the Water System or its appurtenances but would not be a threat to life or health as determined by the State of Colorado.

2.65 Hazard, System

An actual or potential threat of severe damage to the physical properties of the water in the Water System, such as Contamination which would have a protracted effect on the quality of the water in the Water System, caused by a Cross-Connection.

2.66 Impact Fee

The payment to the District for recovery of capital investments associated with major components of the Water System and/or Wastewater System. The Impact Fee assessment is based on the particular impact of the use being connected. As used in these Rules and Regulations, "Impact Fee" may also include the Water System Impact Fee payable to the Upper Eagle Regional Water Authority, if applicable. Refer to Appendix A, Schedule of Fees and Rates. Also known as a tap fee and permitted pursuant to C.R.S. 32-1-1006(1)(g).

2.67 Indirect Discharge or Discharge

The introduction of pollutants into the Sewer System from any non-domestic source regulated under these Pollutant Discharge Regulations and the Industrial Pretreatment Program.

2.68 Individually Metered Residential Account Type

An account type for any residential development in which each Residential Unit is independently owned. Individually Metered Residential Units may be detached or attached by one or more shared walls but do not share common facilities with the attached units, such as plumbing. Water use for each unit is metered and billed separately. Examples of Individually Metered Residential Units include single-family homes, duplexes, townhomes, and row houses. The billing multiplier for Individually Metered Residential Account Types equals the number of SFEs assigned to the account.

2.69 Industrial Fluids System

Any system containing a contaminated fluid or solution in a form or concentration that would constitute a health, system, Pollution or Plumbing Hazard if introduced into the Water System. This may include but is not limited to all types of process waters and "used waters" which may or may not have originated from the Water System, but the quality of which has deteriorated or has the potential to deteriorate to a level considered to be contaminated. Examples of industrial fluids and Industrial Fluid Systems include but are not limited to: chemicals in fluid form; plating acids and alkalis; circulated cooling waters connected to an open cooling tower and/or cooling towers that are chemically or

ARTICLE 2 - DEFINITIONS

biologically treated or stabilized with toxic substances; circulating heating waters or chemicals; natural waters such as from wells, springs, streams, rivers, lakes, dams, ponds, retention pits, irrigation canals or systems; oils, gases, glycerin, glycols, paraffin, caustic and acid solutions and other liquid and gaseous fluids used in industrial, fire-fighting or other purposes.

2.70 Interference

A discharge, which alone or in conjunction with a discharge or discharges from other sources, inhibits or disrupts the Sewer System, its treatment processes or operations or its sludge processes, use or disposal; and therefore, is a cause of a violation of the District's Colorado Discharge Permit System (CDPS) permit or of the prevention of sewage sludge use or disposal in compliance with any of the following statutory/regulatory provisions or permits issued thereunder, or any more stringent state or local regulations: Section 405 of the Act; the Solid Waste Disposal Act, including Title II commonly referred to as the Resource Conservation and Recovery Act (RCRA); any state regulations contained in any state sludge management plan prepared pursuant to Subtitle D of the Solid Waste Disposal Act; the Clean Air Act; the Toxic Substances Control Act; and the Marine Protection, Research, and Sanctuaries Act.

2.71 Irrigation-Only Account Type

An account type for any property that is required to have a separately metered account for irrigation. The billing multiplier for Irrigation-Only accounts is based on the fractional acres (rounded to the thousandths) of irrigated land where one acre equals an irrigation multiplier of one.

2.72 Isolation

The control of a Cross-Connection within a building's plumbing system by the installation of an Approved Backflow Prevention Assembly or means or methods at the potential sources of Contamination.

2.73 kGal

Kilogallon or 1,000 gallons of water. It is the general volumetric measurement for water use.

2.74 Land Use Authority (LUA)

A division of local government; county, towns, and special purpose districts that have been delegated legal authority by the state to adopt and administer land use regulations and local land use plans.

2.75 Major Facility

Any infrastructure determined to be critical to the District's mission to provide water service and wastewater service to customers. Examples of Major Facilities include treatment facilities, raw water supplies, storage facilities, wells, pumping facilities, lift stations, pressure reducing valves (PRVs) and PRV Vaults and others as determined by the District.

2.76 May

Whenever "may" is used herein, it shall be construed as a permissible, but not mandatory direction.

2.77 Mixed-Use Account Type

An account type for any structure containing one or more Residential Units, Accommodation Units, Efficiency Units or Studio Units, and one or more Commercial Units. The billing multiplier for Mixed-Use accounts is based on meter size.

2.78 Multi-Family Residential Account Type

An account type for a residential development in which multiple Residential Units are attached, share facilities such as plumbing, and operated collectively. Multi-Family Residential Units may be owned individually or collectively. Typical examples of Multi-Family Residential Units include apartments and condominiums. For Multi-Family Residential Units water use is metered and billed collectively for the entire building rather than each individual Residential Unit. The billing multiplier for Multi-Family Account Types is based on meter size.

2.79 Non-Potable Water

Water that is not safe for human consumption or that does not meet the requirements set forth in the State of Colorado Primary Drinking Water Regulations.

2.80 Pass Through

A discharge which exits the Wastewater Treatment Plant into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the District's CDPS permit, including an increase in the magnitude or duration of a violation.

2.81 Permanently Non-Metered Account Type

An account type for which water is provided via a non-metered source (such as a private well), but wastewater service is provided by the District. The billing multiplier for permanently non-metered accounts is based on SFE.

2.82 Pollution – see Contamination

2.83 Plan Review Engineer

Responsible for coordination of all Construction Review Team scheduling and communication, development and maintenance of the Rules and Regulations, and approval and acceptance of all new main line development.

2.84 Potable Water

Water that meets the regulatory standards of the Colorado Department of Public Health and Environment and the Environmental Protection Agency for drinking water.

2.85 Preconstruction Meeting

A mandatory meeting including the Applicant, Applicant's contractor, excavator, engineer, and District Inspector during which materials, installation methods, and schedule for construction is discussed and agreed upon. The Preconstruction Meeting will be scheduled a minimum of three (3) days after final approved plan submittal.

2.86 Pretreatment Standard or Standards

Prohibited discharge standards, categorical pretreatment standards, and local limits.

2.87 Private Mains

Any wastewater collector, or any water distribution main that is connected to the District system but not accepted for District ownership, operation, maintenance or repair. Generally, such an installation is designated as private because: (a) it does not conform to the specifications in these Rules and Regulations and the District's Standard Specifications for Main Construction; (b) it is not in the best interest of the District to accept the Main because of special and/or mitigating circumstances; (c) legal title to the Main cannot be transferred free and clear to the District; or (d) the owner of the Main does not wish to convey the Main to the District. Responsibility for operation, maintenance and repairs of private mains are the responsibility of the properties connecting to such main for service.

2.88 Prohibited Discharge Standards or Prohibited Discharges

Absolute prohibitions against the discharge of certain substances; these prohibitions appear in Section 2.1 of Appendix F, Pretreatment Program Regulations.

2.89 Public Use Facility

Facilities operated by Eagle County, any municipality, a special district, schools, churches or other facilities designated for and open for use by the public.

2.90 Reduced Pressure Principle Assembly, Reduced Pressure Zone Assembly (“RPZ”)

An assembly of two independently operating Approved Check Valves with a hydraulic automatic operating differential relief valve between the two Check Valves. The assembly shall be located between two tightly closing (resilient seated) shut-off valves and have four properly located test cocks for the testing of the check and relief valves. The entire assembly shall be an Approved Backflow Prevention Assembly.

2.91 Regional Facilities

Water and/or wastewater systems which provide, or are intended to provide affordable, high quality drinking water and wastewater service to a large population area or more than one service area. Regional facilities provide benefits such as increased economies of scale; operational, administrative, and managerial efficiencies; integration of water resource management; robust regulatory compliance programs; and improved system redundancy. Further, regional facilities can avoid duplicative capital and operating costs associated with interim, non-regional water and wastewater system alternatives.

2.92 Regulations Administrator

An employee of the District authorized to perform duties as described in these Rules and Regulations.

2.93 Residential Unit

A single dwelling unit providing complete, independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking, and sanitation. If areas within a structure or house are designed or arranged with the capability for occupancy that is independent of the rest of the household, that area is classified as a separate Residential Unit. Examples of a Residential Unit include but are not limited to a single-family home, condominium, townhouse, duplex, multiplex, apartment, Efficiency, Studio Unit, lock-off, mobile home, etc. A Residential Unit up to

3,000 square feet in Floor Area is equal to 1.0 SFE. Larger units are considered to be equal to proportionately more SFEs. Refer to the definition of Single Family Equivalent (SFE).

2.94 Rules and Regulations

These Rules and Regulations of the District as adopted and amended from time to time by the Board of Directors which state the policy and procedures by which the Water System and Wastewater System are operated and administered.

2.95 SCADA

The Supervisory Control and Data Acquisition is an industrial controls system used to monitor and operate the District's Water or Wastewater Systems.

2.96 Service Charge

A fixed billing charge applied per Billing Multiplier to fund administration, operation, and maintenance of water and wastewater systems.

2.97 Sewer System

Refer to "Wastewater System".

2.98 Shall

A mandatory direction.

2.99 Significant Industrial User

A User subject to Categorical Pretreatment Standards; or a User that:

1. Discharges an average of twenty-five thousand (25,000) gallons per day (gpd) or more of process wastewater to the Sewer System (excluding sanitary, non-contact cooling, and boiler blowdown wastewater);
2. Contributes a process waste stream which makes up five (5) percent or more of the average dry weather hydraulic or organic capacity of the POTW treatment plant; or
3. Is designated as such by the District on the basis that it has a reasonable potential for adversely affecting the Wastewater Treatment Plants operation or for violating any Pretreatment Standard or requirement.

Upon a finding that a User meeting the above criteria has no reasonable potential for adversely affecting the Wastewater Treatment Plant's operation or for violating any

ARTICLE 2 - DEFINITIONS

Pretreatment Standard or requirement, the District may at any time, on its own initiative or in response to a petition received from a User, and in accordance with procedures in 40 CFR 403.8(f)(6), determine that such User should not be considered a significant industrial user.

2.100 Single Family Equivalent (SFE)

A multiplier that is intended to normalize the water demand of different development types to that of a single-family residence up to 3,000 square feet in size. One SFE is approximately equal to the impact of 2.3 persons occupying a Residential Unit.

2.101 Slug Load or Slug

Any discharge at a flow rate or concentration which could cause a violation of the Prohibited Discharge Standards in Section 2.1 of Appendix F, Pretreatment Program regulations.

2.102 Spring Line

The point of maximum horizontal dimension when looking at an end cross section of a pipe.

2.103 Stub Out

A service line for the benefit of the development of a vacant lot which is connected to the Water or Wastewater System and ends at the property line, with an intent to facilitate the Connection of a Customer's service line to the Water or Wastewater System.

2.104 Submerged Inlet

A water pipe or extension thereof from a Potable Water supply terminating below the flood level rim of a tank, vessel, fixture or appliance which may contain Non-Potable Water.

2.105 Subsurface Utility Engineering-Required Project

If a project meets the requirements of, C.R.S. Title 9, Article 1.5 (6.8) a subsurface utility engineered plan must be submitted.

2.106 Survey

Conducted to assess customer compliance with the district's Backflow Prevention and Cross Connection Control Program and may consist of a physical inspection or a

questionnaire that the customer is required to complete and submit to the District within the specified timeframe.

2.107 Suspended Service

Accounts for which a structure has been demolished, destroyed, condemned, or moved; and a physical disconnection of the water service line from the Water Main or downstream of the curb stop has been verified by the District.

2.108 System Tampering

Any person's misuse of, or damage to, the District's Water or Wastewater System, or any violation of these Rules and Regulations, whether intentional or unintentional. System Tampering may include, but is not limited to: operation of the Water or Wastewater System, including the operation of valves or fire hydrants or obtaining access to facilities without prior written authorization of the District; breaking, connecting to, damaging, defacing, destroying, covering, uncovering, or changing the elevation of the ground surface around any portion of the District's Water System or Wastewater System; modifying any aspect of the Water System or Wastewater System that is not authorized by the District or brings the system out of compliance with these Rules and Regulations; opening or removing of manhole covers, hatches or security devices; the discharge of prohibited wastewater or substances into the Wastewater System; or any action that has the potential to compromise the water quality in the Water System. In addition to any fines or penalties that may assessed by the District, the District may also bring a civil action for damages against any person for System Tampering as authorized by Article 7.5 of Title 40 of the Colorado Revised Statutes; and the District may also request criminal prosecution for any tampering with a water meter, C.R.S. §18-4.506.5.

2.109 System Tampering Fine

A fine to cover the District's staff and administrative costs related to System Tampering and to act as a deterrent to such activities, and may be charged in addition to other costs that may be recoverable by the District. Refer to Article 3, Violator's Liability.

2.110 Tap

The joining of a Water Service Line or Wastewater Service Line to the Water or Wastewater System, respectively, or a Private Main.

2.111 Tie-in

Refers to the physical act of connecting a main line extension to the existing system.

2.112 Tiered Rate Structure

A billing structure for Water Service whereby the monthly billing rate per thousand gallons of metered use becomes more expensive as more water is used. Both the District and Authority employ a five-tiered conservation-oriented rate structure to communicate the value of water to customers through pricing. The tiers for Individually Metered Residential Account Types with combined irrigation and domestic metering are defined as follows :

Tier 1 – Efficient Indoor Use: A use tier that is intended to accommodate the expected volume of water needed for efficient indoor water use.

Tier 2 – Efficient Irrigation Use: A use tier intended to accommodate the expected volume of water needed for efficient outdoor water use.

Tier 3 – Excessive Use: A use tier intended to apply to excessive outdoor water use and whose higher billing rate discourages significant use in this tier due to the potential for water waste.

Tiers 4 & 5 – Unsustainable Use: Water use tiers intended to apply to outdoor water use and whose increased billing rate strongly discourages significant or frequent water use in these tiers due to wastefulness and the unsustainable impact to our environment and infrastructure including water resource capacity, reservoir capacity, water treatment and distribution system capacity, aquifer capacity, and the aquatic health and ecological health of our local streams and rivers that provide our source water.

The Tiered Rate Structure is intended to communicate general guidelines for a customer's efficient use of water. For Individually Metered Residential Account Types all customers pay the same rate for the same volume of water used. For Multi-Family, Mixed-Use, Commercial, and Irrigation-Only Account Types, the amount of water in each tier is determined by multiplying the base tier volume by the accounts' Billing Multiplier. In certain subdivisions and Planned Unit Developments, the tiers may not accurately reflect the area-specific outdoor water use limitations set forth in applicable agreements, land use standards, land use permits, and/or water rights decrees including but not limited to Planned Unit Development Guides, Land Use and Development Codes, Design Standards, Plans for Augmentation, and Water Service Agreements (Land Use Limitation). In such instances, the governing document with the most restrictive limitation on outdoor water use shall define Efficient Irrigation Use amounts, if less than what would otherwise be allowed by the Tiered Rate Structure. Any amount of water used in excess of the Land Use Limitation shall be considered excessive and/or unsustainable, regardless of which billing tier the use falls within, and may be

subject to further enforcement, including but not limited to additional fines and fees under applicable remedies.

2.113 Turn-On and Turn-Off

The manual turning of a Water Service Line valve to either allow water from the Water System to flow freely through the Water Service Line for the use documented in the Application (Turn-On) or to preclude the free flow of water through the Water Service Line (Turn-Off). These terms do not apply to Construction Water Service as provided in Article 4, Construction Water Service.

2.114 Unauthorized Use

Unauthorized Use of the District's Water or Wastewater System by a Customer includes but is not limited to: a change or addition to a Customer's equipment, service, use or property not stated on the Customer's New Account Application that increases the Customer's impact to the Water or Wastewater System; unauthorized Turn-On or Turn-Off of a Water Service or operation of a Water Main to accomplish the same; use of the Customer's service that negatively impacts the District's Water or Wastewater Systems such as backflow to the Water System; discharge of unauthorized materials or Inflow of rainwater or infiltration of groundwater to the Wastewater System; or unmetered water use. Refer to Article 4, Unauthorized Use.

2.115 User or Industrial User

A source of Indirect Discharge.

2.116 Vacuum

A Vacuum Breaker consisting of an air inlet opening and a non-loaded floating check disk valve designed to prevent Back Siphonage only. The device shall not be subjected to continuous static line pressure or backpressure or be installed where it would be under pressure for more than 12 continuous hours.

2.117 Vacuum Breaker, Pressure Type

A Vacuum Breaker, designed to prevent Back Siphonage only, consisting of a spring-loaded Check Valve, a spring-loaded air inlet opening, a tightly closing shut off valve on each side of the device and two (2) appropriately located test cocks. The device shall not be subjected to backpressure. The entire assembly shall be an Approved Backflow Prevention Device.

2.118 Variance

The written authorization from the District to act in a manner not in strict compliance with the District's Standard Specifications for Construction, Rules and Regulations, or policies.

2.119 Warranty Period

The period not less than two (2) years from the date of the Construction Acceptance Letter as issued by the District for any Work. The Warranty Period shall not start until Drawings of Record, recorded easement documents, project cost documents, and Bill of Sale, have been completed, and are received and approved by the District. The Applicant shall furnish to the District a warranty, secured by a surety bond, if requested by the District for all Work, material, services and equipment, and the cost thereof, or for the satisfactory repair or replacement of faulty or improper installation, or improper handling of materials(s) and/or equipment provided by the Applicant. Any repair made on any component constructed and/or installed by the Applicant may, at the sole discretion of the District, extend the Warranty Period.

2.120 Wastewater Main

Any collector or interceptor pipe used as a conduit for conveyance of wastewater in the District's Wastewater Collection System that is owned and maintained by the District.

2.121 Wastewater Service Line

Any pipe or conduit used to provide Wastewater Service from the place where the wastewater is generated to the Wastewater Collection System, including all appurtenant fittings and bedding materials. Maintenance, repair, or replacement of the Wastewater Service Line is the sole responsibility of the Applicant or Customer.

2.122 Wastewater Treatment Plant

The portion of the Sewer System which is designed to provide treatment of municipal sewage and industrial waste.

2.123 Wastewater System

Any network of wastewater collection or interceptor mains, wastewater treatment facilities, appurtenances, accessories, or portion thereof, owned and maintained by the District.

2.124 Water Main

Any distribution or transmission pipe used as a conduit for water, connected to the District's Water System and owned and maintained by the District.

2.125 Water Meter

A measuring device installed on a Water Service Line. The Water Meter includes the meter and all the appurtenances necessary to connect it to the Water Service Line.

2.126 Water Service Line

Any pipe or conduit and related fittings used to convey water to a place of use from a Water Main whether the pipe or conduit is connected to provide service or not; the Connection to the Water Main; and the bedding materials of the pipe or conduit; curb stop, shut off valves; pressure reducing valves; meters; and backflow prevention devices or assemblies located between the Water Main and the shut off valve installed on the downstream side of the Backflow Prevention assembly. Maintenance, repair or replacement of the Water Service Line is the sole responsibility of the Applicant or Customer. As it relates to backflow surveys, per Colorado Department of Public Health and Environment guidelines, Backflow Prevention Cross Connection Control Regulation 11.39, Policy 7, Definition of Single Dwelling means supplied by a separate service line.

2.127 Water Supply Fixture Unit (WSFU)

A unit of measurement used in the International Plumbing Code (IPC) to estimate the probable demand of various types of plumbing fixtures. Water Supply Fixture Units are used to size water supply system components including Water Meters and Water Service Lines.

2.128 Water System

Any network of water distribution or transmission mains, storage tanks or reservoirs, water treatment facilities, appurtenances, accessories, or portion thereof owned and operated by the District.

2.129 Water System Impact Fee (WSIF)

The fee paid to the Upper Eagle Regional Water Authority for recovery of capital investments associated with major components of the Water System. The assessment is based on the particular impact to the capacity of the Water System of the facility being connected. Refer to Appendix A, Schedule of Fees and Rates. Also known as a tap fee and permitted pursuant to C.R.S. 32-1-2006(1)(g) and C.R.S. 31-35-402(1)(f).

2.130 Water Use Rate

A billing rate or tiered rate structure that when applied to the Customer's metered use, results in a portion of the total monthly billing amount due from the Customer to the District.

2.131 Work

Any construction activity on, above, in or around the Water or Wastewater Systems or Water or Wastewater Service Line/Connection, or the construction, installation, modification and/or abandonment described in the approved engineering drawings and submittals by the Construction Plan Approval Letter, and any approved amendments thereto. The applicant is responsible for conformance with the approved plans and all requirements of these Rules and Regulations.

2.132 Any Other Term

Any other term not herein defined shall be as defined or typically used in the water and wastewater utility industry by the American Water Works Association (AWWA), the Water Environment Federation (WEF) or the U.S. Environmental Protection Agency (USEPA). The use of singular may also refer to plural. The use of the masculine gender includes the feminine and neuter genders.

ARTICLE 3 - OWNERSHIP AND LIABILITY

3.1 Liability of District

The District is subject to and avails itself of the provisions contained within the Colorado Governmental Immunity Act, which provisions cannot be waived in whole or in part without the express approval of the District's Board of Directors.

3.2 Compliance with Industrial Pretreatment Requirements

The District has the authority to require all Customers to comply with the Pollutant Discharge Regulations and the Industrial Pretreatment Program and any other applicable law, to require compliance with pretreatment standards; to require monitoring and reporting; to issue notices of violation, compliance orders, cease and desist orders, and, emergency suspensions; to assess a System Tampering fine; to recover costs in accordance with Article 3, Violator's Liability and Appendix F; and to seek judicial remedies for any uses as allowed under the Pollutant Discharge Regulations and Industrial Pretreatment Program. The Pollutant Discharge Regulations and Industrial Pretreatment Program are incorporated and adopted as Appendix F of these Rules and Regulations.

3.3 Ownership of Facilities

All existing mains and treatment works connected with and forming an integral part of the Water and Wastewater System are the property of the District, unless a specific legal contract with a Customer provides otherwise or the District declined to accept, or has not yet accepted the Main or treatment works for ownership. Customers connected to private mains for service are responsible for operation, maintenance, and repairs of the private mains. Private ownership remains valid regardless of whether the District operates, maintains, finances, or constructs all or a portion of the facilities owned by private parties. Transfer of ownership of the Main and treatment works to the District shall be in accordance with the requirements set forth in these Rules and Regulations.

3.4 Water Service

A Water Service Line is owned and maintained by the District from the Tap on the District Water Main up to the property line, edge of easement, or curb stop valve, whichever is closer to the Water Main. The Customer owns and is responsible for the maintenance of the curb stop valve and the remaining portion of the Water Service Line serving the property. If the Water Service Line is tapped to a private main, the Customer shall own and maintain the Water Service Line from the Tap on the Water Main and extending to the entire remaining portion of the Water Service Line serving the property.

The District may construct, finance, repair, maintain, and otherwise affect the Customer's Water Service Line which actions shall not change these principals of ownership.

The Customer shall be liable for the cost of any damage to its property in the case of a leak in, or freezing of, its portion of the Water Service Line. The Customer is liable for any damage to its property caused by fluctuations in water pressure in the Water System, including damage to the Customer's portion of the Water Service Line, the District's Water Meter, the Customer's plumbing system, fire suppression system or property.

3.5 Water Meter

The Water Meter provided by the District for the Customer's Water Service Line is the property of the District. Following the initial installation and inspection of the Water Meter, the Customer shall not disconnect, bypass, remove, replace, repair, relocate or otherwise modify the District's meter. Any such activities may be considered System Tampering and the Customer may then be subject to the provisions of Article 3, Violator's Liability. If any inaccuracy is suspected of the Water Meter to be due to a broken or defective meter, the District will repair or replace the meter at the District's expense. The Customer is liable for the District's cost to repair or replace the District's meter if the meter is damaged due to action or negligence of the Customer, including freezing of the meter or damage due to pressure fluctuations in the District's Water System.

3.6 Wastewater Services

The Customer owns and is responsible for the maintenance of its Wastewater Service Line from the Wastewater Main to the Customer's structure, including any tapping saddle on the Wastewater Main. The District may inspect, construct, finance, repair, maintain, or otherwise affect the Customer's Wastewater Service Line which actions shall not change these principals of ownership.

The Customer shall be liable for the cost of any damages to its property in the case of a blockage or defect in its portion of the Wastewater Service Line.

If the District determines through any means that a Customer's Wastewater Service Line is found to contain Prohibited Discharges the Customer shall be liable for the costs incurred by the District to remedy the situation. Refer to Section 3.10, Violator's Liability.

3.7 Lift Stations

A Wastewater lift station associated with a Customer's Wastewater Service shall be the property of the Customer(s) served by such lift station. Maintenance of such lift station is the sole responsibility of Customer(s) and shall not be the responsibility of the District.

3.8 Existence of Rights-of-Way and Easements

1. The District claims an easement for location of and access to all portions of the Water System and Wastewater System, now or hereafter existing, on, over and in the lands on which the facilities are actually located, whether or not the facilities are located within a recorded easement or other right-of-way.
2. As a condition of service, each Customer and any other person otherwise receiving and accepting service from a Water Service Line and/or a Wastewater Service Line connected to a Water Main or Wastewater Main is deemed to have granted to the District a perpetual easement over the portion of the Customer's property on which any portion of the Water System and/or the Wastewater System is located, regardless of whether such facility is located within a recorded easement or other right-of-way.
3. As a condition of service, all Customers or any other person otherwise receiving and accepting service from a Water Service Line and/or a Wastewater Service Line is deemed to have irrevocably consented to the location of any water or wastewater facilities located on such person's property and shall be deemed to have waived any and all claims against the District, including without limitation any claim for trespass, nuisance, or eviction, and any remedies at law or in equity.
4. The rights provided hereunder shall include the right of the District to reasonably access water or wastewater facilities for any District purpose, including without limitation for the purpose of inspecting, monitoring, testing, constructing, installing, excavating, renovating, expanding, repairing, re-purposing, or replacing such facilities.
5. Prescriptive rights cannot be acquired against the District. If a property owner encroaches upon a District Easement or right-of-way, no property interest shall be acquired which is adverse to the District regardless of the duration of the encroachments.
6. Easements must remain free and clear of any structures or landscaping and have an area of grade and slope that is accessible to District equipment unless an approved easement encroachment agreement has been recorded in the Office of the Clerk and Recorder of Eagle County, Colorado. Payment for the removal and replacement of structures and/or landscaping within the easement

that occurs during work performed by the District is the responsibility of the customer.

7. Certain projects may require the installation of temporary soil nails, tiebacks, or similar earth retention fixtures. The installation of such fixtures are strictly prohibited in District easements above any water or sewer main. The installation of such fixtures below District water or sewer mains may be permitted with an easement encroachment agreement. The applicant may be permitted to install such structures if the following requirements can be met:
 - a. The applicant must prove extenuating circumstances that preclude using other methods of soil retention or stabilization
 - b. The earth retention fixture is sacrificial and can be removed
 - c. The earth retention fixture provides a public benefit

3.9 Conditions of Ownership

The Customer's ownership of a Water Service Line or Wastewater Service Line shall not entitle the Customer to make Unauthorized Uses of the District's Water or Wastewater Systems or to make alterations to the Water Line or Wastewater Service Line or the Water or Wastewater Systems without District approval.

All uses of the Water Service or Wastewater Service, or changes in use of the Service at any time after the initial Connection to the District's Water or Wastewater Systems shall be subject to these Rules and Regulations. When any change in use or modification to an existing Water Service Line or Wastewater Service Line is made, the District may require that all portions of the Water Service Line or Wastewater Service Line, including but not limited to the; Water Meter, meter pit, curb stop or access to Water Service Lines or Wastewater Service Lines or the Water or Wastewater System which District personnel may be required to operate in the performance of their duties, shall be in full compliance with these Rules and Regulations.

3.10 Violator's Liability

Any person found to have engaged in System Tampering will be charged a System Tampering Fee by the District (refer to Article 6, Unauthorized Operation of Water and Wastewater System and Appendix A, Schedule of Fees and Rates). Any person causing damage to the District's Water or Wastewater System by misuse, negligence, or other action, shall be liable for the cost of repair including any study, investigation, or consultant fees incurred. If such violation or damage is in connection with service to a specific property, then such costs shall constitute a lien upon the property as allowed by Colorado law. Any person found to have tampered with the District's Water or Wastewater System may be prosecuted to the full extent allowed under Colorado law;

ARTICLE 3 – OWNERSHIP AND LIABILITY

see Article 2, System Tampering. Actions of a Contractor or third-party on the property of a Customer are the responsibility of the Customer.

Any Customer violating any of the provisions of these Rules and Regulations shall become liable to the District for payment of any fees or costs to the District due for unauthorized service, expense, loss, or damage including attorney fees for enforcement action, occasioned by reason of such violation and may be subject to possible disconnection or suspension of Water Service.

ARTICLE 4 - AUTHORIZATION TO CONNECT TO WATER & WASTEWATER SYSTEMS

4.1 Service Areas

4.1.1 Service within the Eagle River Water & Sanitation District:

Water or Wastewater Service will be furnished in accordance with these Rules and Regulations to property legally included within the Eagle River Water and Sanitation District and subject to the Rules and Regulations of and taxation by the Eagle River Water and Sanitation District. A decision by the District to furnish service is also subject to consideration of impacts to existing Customers. Properties located outside the jurisdictional boundaries of the Eagle River Water and Sanitation District may be served by contract with the approval of the Board of Directors.

4.1.2 Service within the Upper Eagle Regional Water Authority:

Water Service will be furnished in accordance with these Rules and Regulations to property legally included within the jurisdictional boundaries of the member Districts or the Town of Avon, subject to taxation by those entities and subject to these Rules and Regulations of the Upper Eagle Regional Water Authority. A decision by the Upper Regional Water Authority to furnish service is also subject to consideration of impacts to existing Customers.

4.1.3 Including Property into the Eagle River Water & Sanitation District:

Properties to be provided Water or Wastewater Service by the Eagle River Water and Sanitation District must be included into the District service area for Water or Wastewater Service unless contract service is provided for outside the District's service area. Customers who desire service and whose property is both within and outside the District's service area must include all of the property which is capable of being served by the District's facilities. A petition for inclusion shall be filed with the Board requesting that such property be included in the District, on its standard form, by the fee owner or owners of the property to be included, accompanied by a nonrefundable inclusion fee for legal and consultant fees and the estimated cost of processing the petition for inclusion. Any additional costs or legal and consultant fees incurred by the District in excess of the inclusion fee as provided for herein shall be assessed and paid by the Customer prior to approval of inclusion by the Board of Directors. Refer to Appendix A, Schedule of Fees and Rates for the Inclusion fee. The District Board shall hear the petition at a public meeting after publication of notice of the filing of such petition, the place, time, and date of such meeting, the names and addresses of the petitioners, and notice that all persons interested shall appear at such time and place and show cause in writing why the petition should not be granted.

ARTICLE 4 – AUTHORIZATION TO CONNECT TO WATER AND WASTEWATER SYSTEMS

After a property is included into the service area of the Eagle River Water and Sanitation District, a certified copy of the Order of Inclusion entered by the District Court shall be recorded and a copy will be provided to the Customer. Refer to Article 8, Development Approval Process.

4.2 Water Rights Dedication Requirement

Customers proposing new development, re-development or change of use of existing development may be required to dedicate water rights sufficient to serve the proposed uses. All District policies regarding water rights dedication must be followed. Refer to Article 8, Water Rights Dedication Analysis and Article 10, Water Rights Dedication Requirement.

The Applicant shall submit an application and pay all applicable application fees. The Applicant shall be responsible for any and all costs for staff time, legal consultants, engineering consultants, or other expenses that may be incurred by the District in processing the application. Such costs may include, but are not limited to, analyzing water rights and the physical water facility needs of the proposed development, redevelopment or change in use, and to evaluate or adjudicate any augmentation plan or other water court application. These costs are separate and distinct from any application fees. Prior to any review or analysis, the Customer may be required to deposit with the District an amount sufficient to reimburse the District for such costs. Deposited amounts in excess of the costs incurred for the analysis will be refunded.

The District maintains and frequently updates various water planning documents; however, unless expressly noted in any such document, no water planning documents shall be deemed to constitute a "water supply plan" as described under Section 29-20-304(3), C.R.S.

4.2.1 Property in the Upper Eagle Regional Water Authority Service Area

Any request for Water Service for properties newly included into the Upper Eagle Regional Water Authority's service area or for new or expanded water use for a property located within the service area of the Upper Eagle Regional Water Authority that is not included in, or adequately served by, a plan for water augmentation currently available to the Upper Eagle Regional Water Authority, shall be subject to the Authority's Water Dedication Policies.

4.2.2 Property in the Eagle River Water & Sanitation District Service Area

Any request for Water Service for properties newly included into the Eagle River Water & Sanitation District's service area or for new or expanded water use for a property located within the service area of the Eagle River Water & Sanitation District that is not

ARTICLE 4 – AUTHORIZATION TO CONNECT TO WATER AND WASTEWATER SYSTEMS

included in, or adequately served by, a plan for water augmentation shall be subject to the District's Water Dedication Policies.

4.3 Ability to Serve Letter

Refer to Article 8-Development Approval Process

4.4 Infrastructure Acceptance Process

Extensions, modifications, connections to, or abandonments of the Water or Wastewater Systems, or redevelopment of property that impacts existing water and/or wastewater infrastructure, or the completion by the District of any Major Facilities must be approved through the District's Infrastructure Acceptance Process. The Infrastructure Acceptance Process consists of:

1. Construction Plan Approval,
2. Construction Acceptance, and
3. Final Acceptance.

This is described further in Article 9 Infrastructure Acceptance Process of these Rules and Regulations.

4.5 Connection to Water and Wastewater System

4.5.1 Connections per Account

Only one Water Connection and one Wastewater Connection may be made per account per service line.

4.5.2 District Approval Required

Connection shall be made only with District permission. District permission shall not be granted until the following requirements have been met:

1. Inclusion or Operations Agreement
2. Water Rights Dedication or Cash-in-lieu of Water Rights Dedication has been approved;
3. An evaluation has been conducted to determine the current water and wastewater system's ability to supply service to the project and the need for any Main Extensions, Major Facilities, or other system improvements (e.g. Increased size of existing infrastructure and realignment of existing services lines and mains) required to serve the development/redevelopment. Construction Acceptance, for the Main Extension and any other necessary system improvements to which Connection is proposed, has been granted;

ARTICLE 4 – AUTHORIZATION TO CONNECT TO WATER AND WASTEWATER SYSTEMS

4. A building permit for the use related to the proposed Connection has been granted by the appropriate Land Use Authority;
5. The Customer has submitted a complete and accurate Application, to include irrigation and landscaping plans;
6. All required District inspections and field approvals have been obtained; and
7. All applicable Connection Fees and any outstanding fees, as determined by the District, have been paid.

Permission to Connect is evidenced by acceptance of payment of Connection Fees by the District.

4.5.3 Application

Application for Water and/or Wastewater Service, or a change in use or expansion of such service, must be made to the District using the Application. All information requested on the application form must be provided. The District will verify compliance with all applicable requirements, calculate Connection Fees, and generate a Connection Fee invoice for the Customer.

4.5.4 Availability of Service Letter

In lieu of providing a receipt for the payment of impact fees, a customer requesting new service may be required to submit an Availability of Service Letter to a LUA for a building permit submittal to demonstrate that water and wastewater mains are within the vicinity of the property and that water and wastewater service will be provided to the property upon payment of any applicable impact fees.

4.5.5 Meter Sizing

The water meter size, type and manufacturer shall be determined by the District, based on the proposed water use and water flow demand.

4.5.6 Connection Fees

Connection Fees are fees due prior to the meter set turn on. Connection fees for the current calendar year's rate will not be assessed or invoiced unless a complete application has been received, and the application fee has been paid on or before November 30. Connection fees must be paid and received by the District prior to December 31 to qualify for the current calendar year's fee. Connection Fees may include

1. Water and/or Wastewater Impact Fees (District)
2. Water System Impact Fee (Authority)
3. Meter Fee
4. Inspection and other Service Fees

ARTICLE 4 – AUTHORIZATION TO CONNECT TO WATER AND WASTEWATER SYSTEMS

In addition, the District may collect fees due to other associated entities. The fees due from the Customer at the time of Connection will be calculated by the District. All fees due must be paid by the Customer and accepted by the District before the meter set turn on. Refer to Appendix A, Schedule of Fees and Rates.

4.5.7 Treated Water Storage Requirement

The District requires any Customers owning property upon which new development or re-development is proposed, which is located within the District's service area, and which will result in an increase in water use or new water use greater than the water use of the existing development to mitigate the impact of the water use on the water storage capacity of the District. Such mitigation may include development of new storage facilities funded by the developer in addition to the payment of the WSIF by customers establishing new service.

4.5.8 Water Meter Fee

The Water Meter Fee is determined by the cost of the Water Meter specified by the District for the Customer's proposed water use. Refer to Appendix A, Schedule of Fees and Rates.

4.5.9 Disputes

If a dispute arises between the District and a Customer regarding the calculation of Connection Fees or the nature and use of a development as they apply to Appendix A, the dispute shall be resolved in accordance with Article 7, Hearing, Settlement and Appeal Procedures.

4.5.10 Abandonment of Service

When a service is abandoned permanently, the District will make a determination of the status of the Impact Fees, monthly base service fees for Water and Wastewater Service, and the disconnection of the Water Service Line and Wastewater Service Line Connections. A written request to abandon service is required from the property owner. The Customer is required to cap the Water Service Line or Wastewater Service Line at the corporation stop for water and at the Sanitary Sewer Main for wastewater. If the Customer fails to disconnect services as required and at the Customer's cost, the District may perform the work and bill the Customer for costs incurred. Any fees or costs incurred by the District related to the abandonment of service shall be charged to the Customer and, if not paid when due, such fees or costs shall constitute a perpetual lien on and against the property previously served.

ARTICLE 4 – AUTHORIZATION TO CONNECT TO WATER AND WASTEWATER SYSTEMS

4.5.11 Prepaid Impact Fees

Estimated Impact Fees may be paid in advance of Connection. The Customer will be assessed monthly Base Service Charges, Debt Service Bond Charges, and Capital Replacement Program Charges upon the payment of Impact Fees. Impact Fees are not refundable.

4.5.12 Additional Assessment of Fees

An Application shall be submitted to the District by the Customer for an expanded use of an existing Connection within thirty (30) days of the issuance of a building permit for the associated expanded facilities by the applicable Land Use Authority. The Customer shall pay all additional Connection Fees within (30) days of the date of the Connection Fee invoices.

If an expanded use, which in the opinion of the District increases the impact to the District's Water or Wastewater System by the Customer (Unauthorized Use), is discovered by the District, or should any information disclosed on an Application prove at any time to be inaccurate, or should the Customer be found to have omitted any relevant information, the District shall have the right to:

1. Require that the Customer submit a New Account Application within twenty (20) days of the discovery of the expanded use, inaccuracy or omission;
2. Assess additional Connection Fees above originally invoiced fees at the rate current at the time the New Account Application for the expanded use is re-submitted;
3. Disconnect the service to the property served by the account;
4. Back-charge the Customer for monthly Base Service, Debt Service, or Usage Rates due;
5. Charge other fees or interest as provided for in these Rules and Regulations; and/or
6. Make a determination that the expansion of use, inaccuracy or omission is Unauthorized Use and pursue any actions against the Customer as provided for in these Rules and Regulations.

Should the metered water use exceed the amount of water use appropriate for the meter size, the District may require the installation of the correctly-sized meter, as determined by the District. Other adjustments to the Customer account needed to bring the account into compliance with these Rules and Regulations shall be made.

If a recalculation of fees results in the conclusion that the Connection Fees or service fees, if assessed currently, would be in an amount less than the original Connection Fees or service fees paid, no refund shall be made to the Customer.

4.5.13 Transfer of Connection Fees

Any approval of a request for a transfer of Connection Fees shall be at the sole discretion of the District. No Connection Fee paid on behalf of one property, or any portion thereof, may be transferred to any other property unless the following conditions are met:

1. The request to transfer Connection Fees shall be made in writing;
2. The Customer requesting the transfer is the owner of the property for which the Connection Fees, or portion thereof, have been paid and the owner of the property to which the transfer of the Connection Fees, or portion thereof, is being requested. Both properties must be within the service area of the entity that received the original Connection Fees;
3. The Customer requesting the transfer has no outstanding unpaid accounts with the District;
4. The property to which the Connection Fees initially applied has never been connected to the District's system; or, service to the original property is permanently rescinded.
5. The Customer requesting the transfer shall pay to the District the difference between the Connection Fees originally paid and proposed to be transferred, and the Connection Fees assessed on the property to which Connection Fees are requested to be transferred, at rates in effect at the time of the transfer. In no event shall the District make a refund. In the event a Customer transfers only a portion of the total sum previously paid as Connection Fees, the Customer shall retain the remaining Connection Fees on the original property.

Notwithstanding the foregoing, a transfer shall not be authorized if it otherwise conflicts with any District policy, bond covenant or other obligation.

4.5.14 Expansion of Pre-1987 Residential Units

Customers owning Residential Units within the Eagle River Water & Sanitation District Service Area for which Connection Fees were paid prior to January 1, 1987, will be allowed to expand the gross square footage of the Residential Unit up to a total of 3,000 square feet without the assessment of additional Connection Fees. Any additional square footage added above a total of 3,000 square feet will require the payment of additional Connection Fees. The additional square footage allowed without the payment of Connection Fees applies to the original Residential Unit only and may not be applied to another Residential Unit.

ARTICLE 4 – AUTHORIZATION TO CONNECT TO WATER AND WASTEWATER SYSTEMS

4.5.15 Construction Water Service

Connection to the Water System for the use of water for construction prior to the beginning of regular monthly billing. Construction Water Service shall not extend beyond the date of any temporary certificate of occupancy issued by the Land Use Authority.

4.5.16 Temporary Suspension of Service

A Customer may request a Temporary Suspension of Service to an account if the structure being served has been demolished, destroyed, condemned, or moved and a physical disconnection (Air Gap) of the Water Service Line from the Water Main or downstream of the curb stop has been verified by a District Inspector. Such disconnection (Air Gap) must continue throughout the period of suspension. The Customer will be billed Suspended Service Rates monthly for the entire period of suspension, to maintain the approval to Connect.

Before reconnection may occur (closing of the Air Gap), the Customer is required to submit an Application and obtain District permission to Connect.

4.5.17 Unauthorized Use

No Customer shall affect or have an Unauthorized Use of the Water and/or Wastewater System. Refer to Article 2, Unauthorized Use. Upon the discovery of any Unauthorized Use, the District may make a determination that such use is subject to the same provisions as expansion of use discovered by the District and the Customer shall then be subject to the provisions of Article 4, Additional Assessment of Fees. Any Unauthorized Use, once discovered, shall be paid for at the same rate as if that use had been authorized.

4.5.18 Fire Suppression Systems

If a fire suppression system is to be used, a plan of the fire suppression system approved by the appropriate fire protection authority is to be submitted to the District with the New Account Application. The fire suppression service and domestic Water Service Line shall be designed as required by the local fire authority. All fire suppression systems shall meet National Fire Protection Association (NFPA) requirements and additionally shall meet the requirements of all applicable municipal, county, and state building and fire protection codes. All fire suppression systems shall be protected from fluctuating Water Main pressures by a pressure-reducing valve.

As dictated by the State of Colorado, all fire suppression systems shall be equipped with a backflow prevention assembly appropriate to the degree of hazard present on the

ARTICLE 4 – AUTHORIZATION TO CONNECT TO WATER AND WASTEWATER SYSTEMS

site. Refer to Appendix G, Backflow Prevention and Cross Connection Control Program.

4.5.19 Irrigation-Only Accounts

Irrigation-Only Accounts are specific to outdoor water use metered separately from indoor use. For Individually Metered Residential properties, indoor domestic use and Irrigation are metered and billed together, the exception being Irrigation-Only accounts that are utilized for landscaping and irrigation that is managed by a Homeowner's association. All other uses require separate meters for irrigation and indoor domestic use. Some existing Mixed-Use, Multi-Family, and Commercial Account Types may have combined domestic and irrigation use. These uses may remain combined until redevelopment occurs, or the customer requests a separate irrigation account.

4.5.20 Winter Connection

During the winter months (October 15 to April 15), Connections will be made at the District's sole discretion. The Connection location shall be heated or otherwise protected from freezing.

ARTICLE 5 - BILLING FOR WATER AND WASTEWATER SERVICE

5.1 Authorization and Applicability

The information contained in this Article applies to all rates and fees of whatever nature to be levied for the provision of Water and Wastewater Services. The rates and fees for Water and Wastewater Services are set forth in Appendix A, Schedule of Fees and Rates.

5.2 Application of this Article

The rates, fees, and other requirements described in these Rules and Regulations apply to Customers inside and outside the District, but shall not obligate the District with respect to services provided outside the District boundaries.

5.3 New Accounts

At the time the District grants permission to a Customer to Connect, the District will create one Customer account per water meter. Unless otherwise designated, the Customer responsible for the meter, the account, and payment of any fees associated with service to the property, shall be the owner of the property served by the Water or Wastewater System.

The District will issue only one monthly service bill per Customer account. For any Customer account which serves more than one Residential Unit, the responsible party for water and wastewater bills shall be designated at the time the account is established. The designated responsible party may be a person, or a condominium or homeowners' association. As a courtesy, the District will provide a copy of a Customer bill, upon the request of the Customer or designated responsible party, to another party such as a renter. However, the responsibility for payment remains with the Customer or designated responsible party.

5.4 Payment

Payment of any Charge due to the District shall be made within 30 days of the billing date, using U.S. currency. Accepted methods of payment include cash, check, credit card or debit card. Payments made later than 30 days after the billing date are subject to additional charges. Refer to Appendix A, Schedule of Fees and Rates.

5.5 Monthly Billing

Once service and billing to the Customer has been initiated, any Charge due from the Customer to the District will be billed on the Customer's monthly bill.

5.6 Service Charges, Debt Service Bond Charges, Capital Replacement Program Charges and Use Rates

Service Charges, Debt Service Bond Charges, and Capital Replacement Program Charges for Water and Wastewater Services are billed monthly from the date of the prior month's meter read to the date of the current month's meter read and are calculated by applying the Billing Multiplier to the applicable charge associated with the Customer account. Irrigation-Only accounts are billed a minimum service charge equivalent to one acre.

For Water Service, the monthly Use Charge is calculated by applying the Use Rate to the volume of water used in each tier. In an effort to encourage efficient water use, the District employs a Tiered Rate Structure whereby the Use Rate increases as more water is used. See Appendix A for the volume of water in each tier.

For Wastewater Service, the monthly use charge during the winter (reflected on the January through April bills) is calculated by applying the wastewater use rate to the amount of water used. The monthly wastewater charge for the eight billing periods (May through December) is calculated by applying the wastewater use rate to the average monthly water used per month during the winter months (minimum of 5 kGal). This is done to avoid overcharging customers in the summer because customers tend to use more water for outdoor purposes during the summer months.

The Service Charges, Debt Service Bond Charges, Capital Replacement Program Charges and Use Rates are applied when the Water Meter is set and Water Service is turned on to the Customer's property.

5.7 Charges Related to Turn-On and Turn-Off of Service

The Monthly Service Charge and Debt Service Bond Charge do not cease when a water Turn-Off occurs. Payment of all charges due to the District is required in full prior to Turn-On of Water Service. Where Turn Off of Water Service is the result of nonpayment of charges or non-compliance with these Rules and Regulations, a fee will be charged to the Customer for the Turn-On and Turn-Off of service.

5.8 Billing Errors

If the Customer believes the billing statement is in error, the Customer must file, in writing, a notice to the District of the presumed error, and request a review of the billing statement by the District. However, such notice by the Customer shall not constitute sufficient reason for withholding payment of fees due. Upon review by the District, and any revision of the billing statement, any additional fees due from the Customer shall be

paid no later than thirty (30) days from the date of the revised billing statement. Any refund due to the Customer will be credited on a subsequent monthly billing statement.

5.9 Fees for Unauthorized Use

Any Unauthorized Use shall be paid for at the same rate as if that use had been authorized. Unauthorized Use or Connection will be subject to Article 4, Additional Assessment of Fees and Article 3, Violator's Liability.

5.10 Fee for Non-Compliance

If a Customer's service or water use is determined by the District to be not in compliance with these Rules and Regulations, the Customer may be subject to the provisions of Article 3, Violator's Liability and/or may be charged a monthly non-compliance fee until the non-complying condition is remedied. Refer to Appendix A, Schedule of Fees and Rates.

5.11 Collections on Delinquent Accounts

5.11.1 District Notices and Actions

After twenty-five (25) days of non-payment of fees assessed to a Customer account, the District shall assess a Delinquency Charge at the maximum rate allowed by statute on the unpaid balance. At this time, the account will also be declared delinquent. If fees remain unpaid fifteen (15) days after the Delinquency Charge is assessed, a Delinquent Notice is mailed. If the fees remain unpaid for an additional ten (10) days a Notice of Disconnection "door hanger" shall be posted at the property. If payment is not received within 24 hours from posting this notice, the District shall have the right, in its sole discretion, to discontinue service. If service is discontinued, a Turn-Off fee will be added to the amount due. The District will also assess costs related to collection of any delinquent fees, including legal, court, third party, filing or other incidental costs, to the Customer. Until paid, all such delinquent fees shall constitute a perpetual lien on the property served.

5.11.2 Certification of Amounts to County Treasurer

In addition to any other means provided by law, the District may elect, by resolution, at a public meeting held after receipt of notice by the affected parties, including the property owner, to have certain delinquent fees, rates, tolls, penalties, charges, or assessments made or levied solely for Water, Wastewater, or Water and Wastewater Services (including fees for availability of such service and Connection fees), certified to the Eagle County Treasurer to be collected and paid over by the Treasurer in the same

ARTICLE 5 – BILLING FOR WATER AND WASTEWATER SERVICE
--

manner as taxes are authorized to be collected and paid over pursuant to section 39-10-107, C.R.S.

ARTICLE 6 - USE OF THE WATER AND WASTEWATER SYSTEMS

6.1 District Responsibilities

Except as otherwise provided by these Rules and Regulations, the District is responsible for the operation and maintenance of the Water and Wastewater Systems.

6.2 Customer Limitations

Permission to Connect to the Water or Wastewater System is granted to a Customer for the specific uses approved by the District. Following the initial approval to Connect, the Customer shall notify the District prior to any expansion or change of the Customer's property that would affect its Billing Multiplier, water flow demand, backflow conditions or wastewater discharges. The Customer shall notify the District of any change of ownership of the property. The Customer shall not perform work on or operate the Water or Wastewater Systems without the express permission of the District.

6.3 Unauthorized Operation of Water and Wastewater Systems

It is a violation of these Rules and Regulations for any person to use or operate the Water System, including obtaining water at a point that is not an approved Service or Connection, accessing any Water System facilities or introducing any substance to the Water System. Law enforcement officers, District employees, and fire fighters are authorized to confiscate any tool, hydrant wrench or valve key used on the District's Water System without written District authorization and to report the person using or possessing any such tool, hydrant wrench or valve key to the District. Any unauthorized operation of the Water System may be considered System Tampering and therefore subject to the provisions of Article 3, Violator's Liability.

It is a violation of these Rules and Regulations for any person to tamper with facilities or to use or operate the Wastewater System, including the opening or removal of manhole covers or the introduction of any substance to the Wastewater System at a point that is not an approved Service or Connection, without prior written authorization from the District. Law enforcement officers, District employees, and fire fighters are authorized to confiscate any tool that is used to access the Wastewater System and report the person using such tool to the District. Any Unauthorized Use or operation of the Wastewater System shall be considered System Tampering and shall be subject to the provisions of Article 3, Violator's Liability.

6.4 Water and Wastewater Access

Any improvements that inhibit District access to the Water or Wastewater System shall not be permitted. Examples of such improvements include but are not limited to

structures, fences, trees, berms, bushes, walls, or any improvement that would inhibit the District's access to or along the Water or Wastewater System.

6.5 Locating District Facilities

The District is a Tier 1 utility under Colorado's One call Law (Section 1. Article 1.5 of title 9.CRS). The requestor shall utilize the 811 system for locate requests. For private service lines within the Right-of-Way, the District will attempt to locate and mark all water service lines (including curb stops) and sewer service lines within the Right-of-Way to the best of its ability by using available information. Basic line locations will be made free of charge, but the District will not accept financial liability to any party for any costs incurred as a result of an inaccurate location. The District, by providing such location services, does not waive or intend to waive the monetary limitations or any other rights, immunities, defenses and protections provided by the Colorado Governmental Immunity Act, § 24-10-101, et seq., C.R.S., as from time to time amended (the "CGIA").

6.6 Underground Locatable Facilities

All newly installed underground facilities must be electronically locatable per C.R.S Title 9, Article 1.5-103 (10). Tracer wire will be required on all District Facilities to include water and wastewater mains as well as privately owned service lines. See specific requirements in Appendix E.

6.7 Directional Drilling/Boring

All directional drilling and/or boring projects shall be referred to the District. When utilizing trenchless excavation methods, the contractor shall expose underground facilities and visually observe the safe crossing of marked underground facilities per CRS-9-1.5-103-(4)(c) (I) (A). All sewer mains must be televised by the contractor, and footage submitted to the District for review, both prior to the commencement of the work and after the completion of the work. Per CRS 9-1.5-102 (6.8) (B) a Subsurface Utility Investigation must be completed for utility boring projects. See Article 2.99.

6.8 Scheduling Service or Inspections

Customers may be required to schedule District service or inspections from time to time. Appointments for inspections or services, such as Turn-On, Turn-Off, operation of Water Main valves, water meter, transceiver battery changes, flush or flow tests must be scheduled with the District a minimum of two (2) business days in advance. Appointments that have been rescheduled for the following reasons; not ready for inspection, failed, no shows, and not properly scheduled will be charged a Re-Inspection Fee.

6.9 Use of Water System

6.9.1 All Water Use Metered

All water used by a Customer provided by the Water System shall be metered. Any unmetered use is an Unauthorized Use, unless expressly approved by the District, refer to Article 5, Fee for Non-Compliance and Article 3, Violator's Liability.

6.9.2 Water Meter

The Customer shall install the initial Water Meter and the District shall have the right to test, remove, repair, or replace any and all Water Meters. Any meter installed not in accordance with District Specifications (Appendix B, Water and Wastewater Service Line Construction Specifications) shall be immediately re-installed or replaced so as to comply with these Rules and Regulations.

6.9.3 Operation of Meter Bypass

For Water Meter installations plumbed with a by-pass line, by-pass valves shall be installed and may only be operated by District personnel. However, if a failure of the meter occurs and the Customer determines that it is necessary to activate the by-pass line immediately to prevent interruption of Water Service, the District shall be notified within one (1) business day. Failure to notify the District of a break in the seal on operation of the by-pass line shall be considered System Tampering and the Customer shall be subject to the provisions of Article 3, Violator's Liability.

6.9.4 Inaccurate or Broken Water Meter

If the Customer's water use as reported on its monthly bill appears to be inconsistent with the Customer's historical or approved use, the Customer shall notify the District. The District may also discover such an inconsistency through the periodic audit of its records. The District may conduct tests at any reasonable time to determine the accuracy of the Customer's Water Meter.

If a Water Meter is thought to be defective, the District will contact the Customer to make an appointment to repair or replace the meter. If the Customer fails to accommodate the District's request to schedule an appointment, the Customer shall be in violation of the provisions of Article 1, Authority to Access Customer Property.

6.9.5 Backflow Prevention Assemblies

All Backflow Prevention Assemblies determined necessary by the District shall be testable, installed and remain functioning as long as the Water Service Line is connected to the Water System. All such assemblies shall be tested annually by a Certified Cross-Connection Control Technician, see Article 2 of this document for

definitions and Appendix G for requirements. The Customer shall provide the Certified Cross-Connection Control Technician's certification of testing to the District annually.

6.9.6 Turn-On/Turn-Off of Water Service

All non-emergency Turn-On and Turn-Off of Water Service Line at a curb stop shall be performed only by District personnel. During emergencies, a Customer may Turn-Off the Water Service Line at the curb stop valve. The District shall be notified of the emergency Turn-Off and the related circumstances by the Customer within two (2) calendar days. Failure to notify the District of an emergency Turn-Off will be considered System Tampering. Only District personnel shall Turn-On the Water Service Line. For billing related to Turn-On and Turn-Off of the Water Service Line, refer to Article 5, Charges Related to Turn-Off and Turn-On of Service.

The Customer shall allow access to the Customer's property by District personnel for the purpose of Turn-On and Turn-Off of Water Service Line, regardless of the purpose of the Turn-On or Turn-Off, which may be at the Customer's request, in the case of an emergency, or in response to Customer non-payment of charges owed to the District or violation of these Rules and Regulations, refer to Article 1, Authority to Access Customer Property.

Turn-On of a new Water Service Line may not be made until its associated Wastewater Service Line is inspected and connection is made and approved by the District.

6.9.7 Pressure Reducing Valve

A pressure-reducing valve (PRV) shall be installed on all Water Service Lines between the Water Main and each Water Meter and maintained in perpetuity in working order by the Customer, in order to provide protection of the Water Meter, the Customer's plumbing system and any fire suppression system from fluctuating Water Main pressures.

The pressure setting of the PRV shall not exceed 100 psi for domestic service and 200 psi for fire suppression systems.

6.9.8 Repair of Water Service Line

If the District becomes aware of a problem with a Water Service Line which requires repair, the Customer will be notified. The District will determine the method of notice to be provided, which may include telephone, text message, property visit, email, U.S. mail, or such other notice as the District deems appropriate and necessary. The Customer shall institute repair or maintenance immediately. If an emergency is deemed to exist, the District may take any reasonable actions to remediate the emergency to protect public health and safety. This may include, but not be limited to, disconnecting

any water and/or wastewater service line from the District facilities, repairing any water or wastewater service line or taking any other action(s) deemed necessary or prudent to protect the District, the District facilities and/or the customer, owner, or public. In addition, the District shall have the right to effect the repair, the costs of which shall then be added to the Customer's monthly bill and will be subject to the provisions of Article 5, Charges Related to Turn-Off and Turn-On of Service and Fee for Non-Compliance.

6.9.9 Maintaining Fire Hydrant Clearances

Fire Hydrants must be able to be operated at all times. No landscaping, retaining walls, structures, or other obstructions may block access to fire hydrants or bring a fire hydrant out of compliance with these Rules and Regulations. The property owner is responsible for maintaining the following clearances around fire hydrants located on or adjacent to their property: ten (10) feet in the front, seven (7) feet on the sides, and four (4) feet in the back. If the required clearances are not met, District personnel will remove such obstructions after seven (7) days written notice is given or immediately in cases of emergency, the costs of which may be added as a charge to the property owner's monthly bill. The health, safety, and welfare of the public and the critical emergency service nature of fire hydrants require that clearances be maintained at all times. Refer to Appendix C, Standards Details for Water Mains, Fire Hydrant Assembly, for a diagram of the proper clearances.

6.9.10 Construction Water / Fire Hydrant Meter Assemblies

1. Construction Water

Construction water for use on private property shall be taken only through an authorized Water Service Connection and shall be metered. Such water use shall conform to the provisions of Article 4, Construction Water Service.

2. Fire Hydrant Meter Assemblies

The use of a fire hydrant meter assembly is permitted only with the written authorization of the District. A fire hydrant meter assembly includes the meter, backflow preventer, shut-off valves and related fittings. Fire hydrant meter assembly use is allowed only between April 15 and October 15 of each year. No enclosures shall be permitted. The Customer shall protect the fire hydrant meter assembly from freezing. The Customer is responsible for any damage, including vandalism and freezing, to fire hydrants and/or hydrant meters. Only District personnel are permitted to install, move, or disconnect hydrant meters. Customers who attempt to install, move, or disconnect a hydrant meter without District authorization shall be subject to the provisions of Article 3, Violator's Liability. Refer to Appendix A, Schedule of Fees and Rates for deposits, rates and fees related to fire hydrant meter assemblies.

6.9.11 Efficient and Beneficial Water Use

Because water is a limited resource, all Customers of the District shall use water efficiently and only for beneficial purposes in order that the District can continue to assure an adequate water supply to protect the public health, safety and welfare. Customers using water from a source other than the District's Water System for outdoor uses such as landscape watering are encouraged to follow these requirements for Efficient and Beneficial Water Use.

6.9.12 No Wasteful Water Use

Water shall be used only for beneficial purposes and shall not be wasted. Any instance of flagrant runoff or other waste of water shall be considered a violation of these Rules and Regulations.

6.9.13 Irrigation and Outdoor Use Regulations-General

Water for irrigation of lawns, landscaping and other outdoor uses (e.g., car washing, outdoor wash-downs, etc.) shall be used pursuant to these Rules and Regulations. Nothing herein shall prevent the imposition of a total ban on outdoor water use in the event of a water supply emergency, or the creation of additional regulations to meet specific Water System or water supply conditions.

1. Irrigation or other outdoor uses of water shall occur before 8:00 a.m. or after 6:00 p.m.
2. Customers with even-numbered addresses may use water for irrigation and other outdoor uses on Sundays, Wednesdays, and Fridays.
3. Customers with odd-numbered addresses may use water for irrigation and other outdoor uses on Tuesdays, Thursdays, and Saturdays.
4. No irrigation or other outdoor water uses are permitted on Mondays.
5. No irrigation or other outdoor water use shall be permitted at any time through a free-running hose without a nozzle or sprinkler attached.

6.9.14 Irrigation Permits

THIS PROGRAM HAS BEEN SUSPENDED UNTIL FURTHER NOTICE

6.9.15 Use Restrictions – Water Supply Emergencies

If conditions of the Water System or the water supply so limit the availability of water that normal water use may endanger the adequacy of the water supply, the District may declare a water supply emergency and implement emergency water use restrictions and such additional regulations and restrictions that are reasonably necessary to conserve and protect the water supply and to insure an uninterrupted flow of water through the system. Such emergency water use regulations and restrictions shall remain in force

and effect until the District determines that the conditions requiring their imposition no longer exist. Compliance with emergency water use restrictions is a requirement of these Rules & Regulations.

Emergency conditions include but are not limited to: low river flows; impairment of water supply quantity and/or quality; Water Main break; loss of electrical power or pump outages; or loss of system pressure. The District may use local radio and television broadcasts, emergency notification systems, and local signage, as appropriate, to notify the public of such water supply emergency conditions and the necessary water use restrictions.

6.9.16 Filling of Swimming Pools

An Air Gap must be always maintained between the swimming pool and the Water System. Swimming pools will be limited to one filling per year unless draining for repair is necessary. The Customer shall notify the District by telephone two (2) business days prior to the filling of a swimming pool.

6.9.17 Water Features

Outdoor, private water features, such as but not limited to, fountains, waterfalls, and artificial ponds are prohibited in new construction and redevelopment. Pre-existing water features, which exist as of February 25, 2021, shall be entitled to continue to operate. However, modification, enlargement, or substantial improvement of the water feature will not be allowed, and any excessive use of water associated with the property or metered account may trigger the need to remove said water feature. Water features are not allowed to be placed in District easements.

6.10 Use of Wastewater System

6.10.1 Prohibited Discharges

Customers, Users, or Industrial Users (as defined in Article 2 of this document and in Appendix F, Pollutant Discharge Regulations and Industrial Pretreatment Program) shall not discharge, or cause to be discharged, any storm water, surface water, drainage from garage floor drains, groundwater, roof runoff, subsurface drainage, or any prohibited discharges listed or described in Appendix F to the Wastewater System.

6.10.2 Pretreatment Facilities

Where necessary, in accordance with the Pollutant Discharge Regulations and Industrial Pretreatment Program, the Customer shall provide, at its expense, such Pretreatment Facilities as may be necessary to treat any Indirect Discharge prior to discharge to the Wastewater System. Such facilities shall be maintained continuously in satisfactory and effective operation by the Customer, at its expense.

6.10.3 Repair of Wastewater Service Line

If the District becomes aware of a problem with a Customer's Wastewater Service Line, the Customer will be notified by first-class mail that the Wastewater Service Line needs repair. The Customer shall institute repair or maintenance immediately. If satisfactory progress towards repairing the service is not made in a timely manner, or the District determines that environmental or property damage is being caused or may be caused by the Wastewater Service Line problem, the District may Turn-Off the Water Service Line until it is repaired. In addition, the District shall have the right to affect the repair, the costs of which shall then be added to the Customer's monthly bill and will be subject to the provisions of Article 5, Charges Related to Turn-On and Turn-Off of Service and Fee for Non-Compliance.

If trenchless technology is used to replace or repair a Wastewater Service Line, the Customer shall notify the District two (2) days prior to the repair work. The connection between the Wastewater Service Line and the Wastewater Main must be televised from the Wastewater Main before and after repairs are made and video records showing the connection must be provided to the District.

6.10.4 Draining of Swimming Pools and Hot Tubs

In order to protect instream water quality, it is recommended that swimming pools and hot tubs be drained to the wastewater collection system. The following guidelines must be followed prior to discharge:

1. Swimming pools will be limited to one draining per year unless draining for repair is necessary. The Customer shall notify the District by telephone or email two (2) business days prior to the draining of a swimming pool. It is not necessary to notify the District about the draining of a hot tub or spa.
2. The Customer may drain to their wastewater service line; this includes drains in the home/business or the private property sewer cleanout. The Customer shall not open or drain directly to a District manhole.
3. The chlorine or bromine levels must be below 0.1 mg/L.
4. The pH of the discharge water must be between 6.5 and 8.5.
5. The discharge water must be free of any unusual coloration.
6. Settled material should not be discharged with pool or hot tub water.
7. The drainage rate must be controlled to less than 100 gallons per minute.

If it is not possible to drain the pool or hot tub to the collection system, it is recommended that the Customer follow the currently adopted version of the Colorado Department of Health and Environment's (CDPHE) Low Risk Discharge Guidance – Discharges from Pools, Fountains, and Other Similar Type Facilities.

6.10.5 Grease Interceptor

Grease interceptors, also known as grease traps, are required to be installed and maintained in proper working order for all restaurants, bakeries, or food and beverage preparation establishments from which wastewater discharges containing oil or grease could be made. Grease interceptors shall be cleaned of collected materials (fats, oils and grease) by the Customer on a regular basis to ensure effective operation. The District has the authority to inspect grease interceptors and to request and review operating records at any reasonable time to ensure that proper maintenance is being performed. The addition of chemicals and biological additives to grease interceptors used for dissolving grease are prohibited.

If at any time the District determines that the wastewater contains grease or grease dissolving chemicals having an adverse effect on the Wastewater System, the Customer will be notified and required to perform remedial maintenance and cleaning immediately. See Appendix F for program requirements.

If no grease interceptor is in place or an existing grease interceptor is not operable, a new grease interceptor shall be installed by the Customer. At a minimum, the most recently adopted State of Colorado Plumbing Code shall be met regarding the installation and sizing of a grease interceptor.

Failure to comply with the provisions of this section shall result in a Charge or the suspension of water service as defined in Article 3, Violators Liability.

6.10.6 Control Manhole

When required by the District, any Customer served by a Wastewater Service Line carrying an Indirect Discharge shall have and maintain, at the Customer's expense, a suitable control manhole on the Wastewater Service Line to facilitate observation, sampling, and measurement of the wastewater by the District. A control manhole on the Wastewater Service Line for monitoring wastewater is required for all restaurants and bakeries. All measurements, tests, and analyses of the characteristics of wastewater containing Indirect Discharges shall be determined in accordance with Appendix F, Pollutant Discharge Regulations and Industrial Pretreatment Program. In the event that no control manhole has been required or installed, the District will specify an appropriate sampling point.

ARTICLE 7 - HEARING, SETTLEMENT AND APPEAL PROCEDURES

7.1 Application

The Hearing, Settlement and Appeal Procedures established by this Article shall apply to all complaints concerning the interpretation, application, and enforcement of these Rules and Regulations of the District, as they now exist or may hereafter be amended. The Hearing, Settlement and Appeal Procedures established by this Article shall not apply to the following complaints:

1. Complaints that arise with regard to personnel matters. These complaints shall be governed exclusively by the rules set forth in the District's Employee Handbook.
2. Any other complaint which does not concern the interpretation, application, or enforcement of these Rules and Regulations of the District.

7.2 Variance

Where the strict and literal interpretation of these Rules and Regulations may cause undue difficulty or hardship to the Applicant, the Applicant may request a Variance. The Variance request shall be submitted to the Construction Review Team who shall have the authority to grant or deny the request. The Construction Review Team will review the Variance based upon the following criteria:

1. The granting of a Variance will not constitute a grant of special privilege.
2. The granting of a Variance will not be detrimental to public health, safety, or welfare or injurious to other properties or improvements.
3. There are exceptional or extraordinary conditions applicable to the site.
4. There are pre-existing conditions causing undue hardship.
5. Cost or inconvenience shall not be considered in granting a Variance, such as road cuts and the existence of other subsurface utilities; and
6. The Applicant has exhausted all efforts to comply with the Specifications.

The Applicant shall accompany a variance application with a written letter stating the need for the variance and how it meets the above listed criteria.

7.3 Initial Complaint Resolution

Complaints concerning the interpretation, application, or enforcement of these Rules and Regulations of the District shall first be presented to the District staff with which the Customer has been communicating related to the complaint. If a resolution is not reached, the complainant may submit a written complaint. District staff will then respond to the complainant by making a full and complete review of the allegations contained in

the complaint. District staff will take such action and/or make such determination as it deems warranted. Such action or determination will be documented in a letter to the complainant issued within sixty (60) days of the written complaint.

If the complainant is dissatisfied with the action or determination of District staff, the complainant may initiate the Expedited Appeal and Settlement Procedure.

7.4 Expedited Appeal and Settlement

To initiate the Expedited Appeal and Settlement procedure, the complainant shall file a written request to initiate the procedure with the District's Regulations Administrator, who will be appointed by the General Manager. The Regulations Administrator is authorized to consider all circumstances, including the complainant's actions or inactions in the situation, and the written action or determination of the District staff. Following an investigation of the facts of the complaint for purposes of facilitating an equitable resolution, the Regulations Administrator is empowered to take an action, render a determination, or offer a settlement, which he/she has determined to be just and fair. The Regulations Administrator shall document such action, determination or settlement offer in a letter issued to the complainant no later than sixty (60) days after the date of receipt of the complainant's request to initiate the Expedited Appeal and Settlement procedure.

If the complainant rejects the action, determination or settlement offer of the Regulations Administrator, the complainant may request a Formal Appeal.

7.5 Formal Appeal

To initiate the Formal Appeal procedure, the complainant shall file a written request for appeal of the Regulations Administrator's decision to the General Manager within thirty (30) days from the date written notice of the action, determination or settlement offer was mailed to the complainant.

If receipt of the request for a hearing is timely and if all other prerequisites prescribed by these Rules and Regulations are being met, the General Manager may hear the appeal himself/herself, or may appoint a hearing officer, other than himself/herself, to hear the appeal. Either the General Manager or such hearing officer will conduct a hearing at the District's convenience and upon not less than ten (10) days written notice to the complainant of the date, time and place of the hearing. Every effort will be made to conduct the hearing within thirty (30) days after the receipt of the request for Formal Appeal. The hearing shall be conducted in accordance with and subject to all pertinent provisions of these Rules and Regulations.

7.6 Conduct of Hearing

At the hearing, the General Manager or the hearing officer shall preside and will hear the appeal. The complainant and representatives of the District shall be permitted to appear in person, and the complainant may be represented by any person of his/her choice, including legal counsel.

The complainant or his/her representative and District representatives shall have the right to present evidence and arguments; the right to cross-examine any person; and the right to oppose any testimony or statement that may be relied upon in support of or in opposition to the action or determination of the District staff, as made under Article 7, Initial Complaint Resolution or the action, determination or settlement offer of the Regulations Administrator made under Article 7, Expedited Appeal and Settlement. The General Manager or hearing officer may receive and consider any evidence which he/she determines has probative value commonly accepted by reasonable and prudent persons in the conduct of their affairs. The General Manager or hearing officer may ask questions of any representative in order to clarify further an issue relevant to the complaint and appeal.

7.6.1 Decision on Appeal

The General Manager or hearing officer is authorized to determine whether to affirm, amend, or reverse the determinations made under Article 7, Initial Complaint Resolution and Expedited Appeal and Settlement. The General Manager or hearing officer may consider all facts and circumstances, and the evidence presented at the hearing, including the complainant's actions or inactions in the case, and whether determination under Article 7, Initial Complaint Resolution and Expedited Appeal and Settlement are consistent with these Rules and Regulations and equitable to the District and the complainant. The complainant bears the burden of showing that grounds exist to reverse or amend the decisions under Article 7, Initial Complaint Resolution and Expedited Appeal and Settlement.

The written decision of the General Manager or the hearing officer will be mailed to the complainant within forty-five (45) days after the date the hearing is conducted and closed.

If the complainant rejects the decision of the General Manager or hearing officer, the complainant may request to appeal the decision of the General Manager or hearing officer to the District Board of Directors.

7.7 Appeal to the Board of Directors

To initiate an Appeal to the District Board of Directors, the complainant shall file a written request for appeal of the General Manager's or hearing officer's decision to the General Manager within thirty (30) days from the date written notice of the General Manager's or the hearing officer's decision was mailed.

The request for an appeal shall set forth, with specificity, the facts or exhibits presented at the hearing upon which the complainant relies and shall contain a brief statement of the complainant's reasons for the appeal. The General Manager or the hearing officer will compile the Record of the hearing for the Board of Directors, consisting of:

1. Minutes of the hearing (Article 7, Formal Appeal);
2. All exhibits or other physical evidence offered and reviewed at the hearing; and
3. A copy of the written decision of the General Manager or hearing officer.

7.7.1 Conduct of Board Hearing

The Board shall consider the complainant's written request for appeal and the Record of the hearing (Article 7, Formal Appeal) at the next regularly scheduled meeting of the Board held not earlier than ten (10) business days after the filing of the complainant's request for appeal to the Board of Directors. Such consideration shall be limited to a review of the Record of the hearing, and the complainant's written request for appeal. The complainant or complainant's representative and the General Manager or his or her designated representative shall be permitted to address the Board during the Board's consideration of this appeal for no more than three (3) minutes each. No further evidence or argument shall be presented by any party to the appeal and there shall not be any right to a hearing de novo before the Board of Directors.

7.7.2 Board Decision on Appeal

The Board shall make written findings and issue a decision concerning its disposition of the appeal. The Board may affirm, amend or reverse the decision of the General Manager or hearing officer. A notice of the decision shall be sent by mail to the complainant within thirty (30) days after the Board meeting at which the appeal is heard. The Board of Directors' decision on appeal shall be final.

7.8 Notice

A complainant shall be given notice of any hearing before the General Manager or hearing officer, or before the Board, by mail at least ten (10) days prior to the date of the hearing, unless the complainant consents to a waiver of formal notice. Notice is deemed given when placed in regular U.S. mail, postage prepaid, to the address in the District records for the complainant.

ARTICLE 8 - DEVELOPMENT APPROVAL PROCESS

8.1 General

All inquiries, applications and plan submittals for development within the District's service area shall be initiated online at:

<https://erwsd.centricityweb.com/>

Review of applications and submittals are conducted by the District's Construction Review Team (CRT). To schedule an appointment, contact:

The Construction Review Team

CRT@erwsd.org

An Applicant or Applicant Representative may request a meeting at any time during the Applicant's project planning period to seek clarification of submittal requirements of the Applicant.

Applicants proposing to receive service for new or expanded water uses and/or new wastewater discharges (not previously approved by the District), must complete the Development Approval Process in order to receive service from the District's water and/or wastewater systems. New and expanded service generally also requires a land use application through a Land Use Authority (LUA). The District works with local LUAs to coordinate its approvals with the LUAs approval process.

The District's Development Approval Process is described below and includes:

1. Initiation of Development Approval Process
2. Inclusion into Service Area (if applicable)
3. Water Rights Dedication Analysis
4. System Capacity evaluation
5. Treated Water Storage Dedication Analysis
6. Conditional Capacity to Serve Letter Issued
7. Completion of Water Rights Dedication Process
8. Ability to Serve Letter Issued
9. Infrastructure Acceptance Procedure, refer to Article 9.

8.2 Initiation of Development Approval Process

The Development Approval Process is initiated by an Applicant or Applicant Representative upon submission of a conceptual plan showing the location of the

proposed development to the Construction Review Team (CRT) for review and the payment of applicable application fees. Submission requirements include the following:

1. Legal Description of Property
2. Vicinity Map of development
3. Description of land use (current and proposed), including:
 - a. number of dwelling units (with square footage)
 - b. commercial and mixed uses if applicable (with square footages)
 - c. current and proposed zoning
 - d. total acreage of irrigated areas

8.3 Inclusion into Eagle River Water and Sanitation District or the Service Area of the Upper Eagle Regional Water Authority

Refer to Article 4.

8.4 Water Rights Dedication Analysis

Applicants proposing new development, re-development or change of use of existing development may be required to dedicate water rights sufficient to serve the proposed uses. All District policies regarding water rights dedication must be followed. Refer to Article 10, Water Rights Dedication Requirements.

Water rights dedication sufficient to serve the water uses of the proposed development or a cash payment in lieu of a water rights dedication at the Board of Directors' discretion must be made by the Applicant to obtain service. To determine whether a dedication is required, a proposed dedication is adequate, or a cash-in-lieu payment is acceptable to the Board of Directors, the Applicant shall pay the applicable application fee and submit an application subject to the following requirements:

1. Completion of a Water Demand Worksheet (available upon request from the District).
2. A request for cash-in-lieu of water rights dedication or information regarding potential water rights to be dedicated including all applicable water court decrees.
3. A deposit may be required to cover additional costs incurred by the District for staff time, legal consultants, engineering consultants, or other expenses that may be incurred by the District to analyze water rights and the physical water facility needs of the proposed development, redevelopment, or change in use and to evaluate or adjudicate any augmentation plan or other water court application. Deposited amounts in excess of the costs incurred for the analysis will be refunded.

The Board of Directors approves/denies the application for water rights dedication or cash in lieu payment. Resolution is defined as either:

1. A determination that no water rights dedication is required;
2. An executed Water Rights Dedication Agreement is in place; or
3. A Water and Wastewater Service Agreement has been executed, the Board of Directors has accepted cash-in-lieu of water rights dedication payment, and the Applicant has paid all fees in full.

8.5 Determination of Sufficient System Capacity

Evaluation of the proposed water and wastewater infrastructure needed to serve the proposed development or redevelopment includes an analysis of the impacts the proposed development's/redevelopment's water uses and wastewater demands will have on existing or future infrastructure of the District, treatment and system capacity, regulatory compliance, rates and water supplies. CRT and the District's consultants will determine system impacts. If deemed necessary, the CRT may require a third-party review by its system modeling and engineering consultants to determine the effect of the proposed connection and demand on the District's existing infrastructure and treatment capacity. The Applicant may be required to up-grade/modify existing infrastructure to accommodate the proposed development and its impact to the water and wastewater infrastructure, at the Applicant's cost.

8.6 Determination of Treated Water Storage Dedication

An Applicant with property upon which new development or redevelopment is proposed, which is located within the District's service area, and which will require an increase in water use or new water use not allowed by existing Connections or zoning, is required to provide treated water storage adequate to meet the needs of the proposed development. This requirement may be fulfilled by funding the design and construction of a new storage facility (Major Facility) or by funding existing storage capacity through payment of impact fees by the customers.

The amount of treated water storage required shall be equal to the combined volumes of water calculated to meet the need for equalization storage, emergency storage, and fire flow storage for the development. Equalization storage shall be equal to 25 percent of average daily demand (ADD); emergency storage equal to 100 percent of ADD; and fire flow storage based on the greatest fire flow required by the fire protection agency having jurisdiction in the service area of the proposed treated water storage reservoir. The CRT will work with the applicable fire protection agency to determine fire storage

requirements using best practices. If a new treated water storage facility is required, it will be implemented as a Major Facility.

If the proposed development is to be served by a new treated water storage facility, Applicant shall provide estimated size and capacity calculations, geotechnical information, and conceptual plans as part of the plan submittal.

8.7 Conditional Capacity to Serve Letter

The Applicant may be required to obtain an Ability to Serve Letter from the District by a LUA or lending entity before the conditions to obtain an Ability to Serve Letter can be met. In this case, the District will issue a Conditional Capacity to Serve Letter to the Application which states that the District is willing and able to serve the development if all conditions for an Ability to Serve Letter are satisfied. These conditions may include but not be limited to the inclusion of the property into the service area of the District, obtaining all necessary land use approvals for the development, completion of the District's water rights dedication process, execution of a water and wastewater service agreement, construction of water and wastewater infrastructure necessary to serve the development, and the payment of all applicable fees. This letter does not commit the District to serve the development if the conditions to obtain an Ability to Serve Letter are not met.

Prior to the issuance of a Conditional Capacity to Serve Letter, the Applicant may be required to deposit funds to secure the conditional commitment of water rights to the proposed development in accordance with the District's water rights dedication policy. The Conditional Capacity to Serve Letter will include an expiration date and may be extended following a written request for extension by the Applicant and subject to approval by the Board of Directors.

8.8 Ability to Serve Letter

The District will issue an Ability to Serve Letter to the Applicant that satisfies the requirements of § 29-20-304 (3), C.R.S. once the following conditions are met:

1. The property proposed for development has been included within the Eagle River Water and Sanitation District service area;.
2. Resolution of all water rights dedication issues to the satisfaction of the District; and
3. All impacts of the proposed development to the Water or Wastewater Systems of the District have been identified and agreed upon between the Applicant and the District.

ARTICLE 8 – DEVELOPMENT APPROVAL PROCESS

An Ability to Serve Letter may contain conditions that must be satisfied before the development can receive water service such as the construction of water and wastewater infrastructure and the payment of all applicable fees.

ARTICLE 9 - INFRASTRUCTURE ACCEPTANCE PROCESS

9.1 General

All water or wastewater mainline extensions, replacements, modifications, reconfigurations, expansions of capacity, or abandonments as a result of development or redevelopment within the District's service area shall be made at the expense of the Developer or Applicant. Prior to excavation, the Developer or Applicant shall locate, survey, pothole, and/or videotape at its expense, any existing water mainlines and facilities that may potentially be affected by construction activities. No work shall commence without the District's written Construction Plan Approval. Construction Plan Approval will not be granted without inclusion into all applicable District boundaries, issuance of an Ability to Serve letter or the determination that the letter is not required, resolution of all water rights dedication requirements, and payment of any required fees.

All inquiries, applications and plan submittals for water and wastewater Main extensions within the District's service area shall be initiated online at:

<https://erwsd.centricityweb.com/>

Review of applications and submittals are conducted by the District's Construction Review Team (CRT). The CRT meets at the District offices every Tuesday at 1:00 p.m. To make an appointment, contact:

Plan Review Engineer

CRT@erwsd.org

An Applicant or Applicant Representative may request a meeting at any time during the Applicant's project planning period to seek clarification of District specifications, submittal requirements or the Infrastructure Acceptance Procedure. Submission of plans for District review must be made in person by the Applicant or Applicant's Representative at a regularly scheduled meeting of the CRT.

The District's Infrastructure Acceptance Procedure is described below and includes:

1. Construction Plan Approval
2. Construction Acceptance
3. Final Acceptance

9.2 Construction Plan Approval

No Work may commence prior to Construction Plan Approval. The District will review all submittals for conformance with the District's Standard Specifications for Water and

Wastewater Main Line Construction and other applicable Rules and Regulations and either approve the submittal or return it to the Applicant for clarification, modification or correction. The Applicant is responsible for compliance with the Districts' Standard Specifications for Water and Wastewater Main Line Construction and with any site-specific special conditions that may be reasonably required. The Standard Specifications for Water and Wastewater Main Line Construction take precedence over any plan reviews performed by the District unless a written Variance has been granted. The District is not responsible for omissions that may occur during its plan review process.

9.2.1 Construction Plan Submittal Requirements

One (1) set of each submittal item is required electronically. The following submittals are required per CDPHE standards unless deemed not applicable by the Construction Review Team (CRT):

1. An overall or master plan showing the location of the Work, area to be developed and any adjoining proposed development by the Applicant:
 - a. Prior to submitting any master plan, Applicants are required to meet with District staff to review the project concepts and obtain direction from the District.
 - b. Provide a conceptual layout of proposed infrastructure. This shall include all dry and wet utilities.
 - c. Prepare and submit a basis of design report signed and sealed by a professional engineer licensed in the State of Colorado that supports the design of the proposed layout of the infrastructure. Hydraulic modeling using industry standard software programs are required for water distribution and wastewater collection pipe design. Please consult the district prior to proceeding with your specific software choice. Modeling results must be provided with the basis of design report.
 - d. The master plan must be accepted and approved by the District prior to submitting any construction drawings.
2. Detailed and complete construction drawings of the Work including:
 - a. A plan view drawing of the proposed Water and Wastewater Systems;
 - b. The proposed alignment and size of the Water and Wastewater mains. The proposed location, size, materials and details of all system attributes, including but not limited to: valves, fire hydrants, fittings, manholes, services, drop manholes, energy dissipation devices, bedding, backfill, final surface treatment, insulation and any connections from private lift stations, etc.;
 - c. Water and Wastewater System profiles with storm sewer and utility crossings shown;
 - d. Points of Connection to existing facilities;

ARTICLE 9 – INFRASTRUCTURE ACCEPTANCE PROCESS

- e. Location and configuration of any existing or proposed property lines, rights-of-way, floodplain boundaries, easements, roads, driveways, structures, cut or fill slopes, guard rail, drainage features, other utilities, berms, landscaping, hardscape, street heating systems or topographic features, and
 - f. Water and Wastewater System engineering details shall follow the District's standard details incorporated in Appendix C, Appendix D, and Appendix E. unless a Variance is being requested.
 - g. A completed engineer's checklist is required with each plan submittal.
 - h. If the project meets the requirements of C.R.S., Title 9, Article 1.5 (6.9) "Subsurface utility engineering-required project" a copy of the S.U.E report must be submitted with the plan submittal.
 - i. A complete tracer wire system plan incorporating all the requirements of Appendix E.
3. Plan requirements shall:
- a. Be based on field surveys and shall reference land corners or other official survey control points such that the facilities can be accurately staked for installation and can be readily located after installation for maintenance and connecting and control.
 - b. Conform to a scale of one inch (1") equals twenty feet (20') on 24-inch by 36-inch material. Larger scales shall be used when necessary to adequately show specific details of mains, Connections, and other installations;
 - c. Show sufficient adjacent area to show the relation of new facilities to existing facilities. Existing Water and Wastewater System attributes shall be identified on the plans with District's mapping specifications; and
 - d. Show station numbers for Water and Wastewater Service Lines, valves and fittings, fire hydrants, thrust blocks, elbows, bends and deflections with the degree of angle, stream crossings, manholes, etc.
 - e. Include standard District Plan Notes for both water and wastewater.
 - f. Include geotechnical reports for both soil corrosivity and groundwater.
4. Plan requirements may:
- a. Include average daily and peak system demands that will be generated by the development to be served by the Work and calculations showing that proposed system capacity is adequate to serve the demand;
 - b. Include any geotechnical reports or information including slope stability evaluations, used in the development or design of the Work.
 - c. Include restoration and landscaping adequate to prevent erosion caused by surface run off. Landscaping and restoration construction shall be designed in such a manner that minimal future maintenance will be required.

If necessary, the CRT may require third party review by the District's system modeling consultant to determine the effect of the proposed Work and/or demand on the District's

existing infrastructure and treatment plant capacity. The Applicant may be required to up-grade and/or modify the existing infrastructure to accommodate the development and its demand on the District's system. Any required up-grades and/or modifications to the existing Water or Wastewater System may be at Applicant's expense, as determined by the District. If the Applicant's development necessitates the construction of Major Facilities, the Applicant will enter into an agreement with the District to provide funding for the design and construction of such facilities.

Once a submission item has been determined to be complete and acceptable to the CRT, a final copy shall be prepared, stamped and signed by a Registered Professional Engineer or Registered Land Surveyor, as appropriate, and submitted.

9.2.2 Determination of Corrosive Soils

The Applicant will be required to perform and provide to the District the results of a soil corrosivity test within the proposed project area, or confirmation from a licensed geotechnical engineer that corrosive soils are not known to exist in the project area. Soils shall be sampled at a frequency and locations recommended by the geotechnical engineer to adequately assess the risk of corrosive soils. Soils shall be sampled upon the methodology outlined in Appendix A of AWWA C105 (with additional groundwater elevation and Chloride data) and scored based on the DIPRA-Design Decision Model (DDM). If soils are determined to fall within zones 4 or 5 of the DDM matrix, the Applicant must include an engineered corrosion mitigation plan as part of the construction plan submittal.

Link- <https://www.dipra.org/phocadownload/new/CorrosionControl-DesignDecisionModel.pdf>

9.2.3 Determination of High Groundwater

The Applicant will be required to perform and provide to the District the results of a soils/geotechnical test within the proposed project area to confirm the absence or presence of high groundwater. Soils shall be sampled at a frequency and locations recommended by the geotechnical engineer to adequately assess the presence of high groundwater. If high groundwater is proven to be present, the Applicant must include an engineered mitigation plan as part of the construction plan submittal.

9.2.4 Major Facilities

Early in the development approval process, the Applicant will present conceptual drawings and calculations to the CRT for a determination of the need for Major Facilities. Major Facilities will be determined and identified on a case-by-case basis by the District, but in general will include the following:

Table 9.1: Major Facilities

<u>Water</u>	<u>Wastewater</u>
Treatment Facilities	Treatment Facilities
Treatment Facility Expansions	Treatment Facility Expansions
Raw Water Supply	Mainline Lift Stations
Supply Wells	
Pumping Facilities	
Storage Facilities	
PRVs and PRV Vaults	

The Applicant will collaborate with the District to enter into an agreement for the design and construction of Major Facilities, or provision for the construction or upgrade of Major Facilities may be included in a Water Service Agreement or a Sewer Service Agreement between the District and the Applicant. The District shall provide all project management services for Major Facilities, including planning, design, and engineering of all Major Facilities; preparation of bid documents, preparation of construction cost estimates, bidding the project, awarding the contract, and managing construction to completion and throughout the warranty period. Developer shall be solely responsible for providing all of the funds necessary for planning, design, and construction of the Major Facility.

9.2.5 Regional Facilities

The District will not own, manage, or operate water and wastewater systems which are not designed as regional Facilities. Developments requesting to construct, finance, and utilize interim, non-regional facilities will be reviewed on a case-by-case basis. Such interim, non-regional water and wastewater systems may be permitted to operate within the District's service area at the discretion of the District Board of Directors subject to the following minimum criteria, and any other conditions that may be imposed by the Board:

1. The non-regional water or wastewater systems are designed and constructed in accordance with the District's Rules and Regulations;
2. The non-regional water or wastewater systems are designed in such a manner that they can be integrated into future regional systems capable of serving adjacent properties without additional cost to the District; and

3. The non-regional water or wastewater systems utilize water resources efficiently.

9.2.6 Special Conditions

When applying for a main extension, special conditions that involve another agency, such as crossing a railroad or highway, may exist. All conditions of the appropriate agency must be satisfied. All applicable designs, drawings and/or calculations or special conditions required by other reviewing agencies or entities of the Applicant's project shall be incorporated into the Applicant's submittal to the District. The District is not responsible for ensuring compliance with the requirements of other reviewing agencies. Should a conflict arise between the requirements of another reviewing agency and the District's requirements the more stringent plans, requirements and/or specifications yielding a higher quality product, as determined in the sole discretion of the District, shall prevail.

9.2.7 Construction Plan Approval Letter

A Construction Plan Approval Letter grants the Applicant permission to commence the work. A Construction Plan Approval Letter shall not be granted until:

1. Inclusion of the property to be served in the Eagle River Water and Sanitation District, the service area of the Upper Eagle Regional Water Authority, or a service contract with the District or Authority is completed;
2. All water rights issues pertaining to the Applicant's project have been resolved to the satisfaction of the District;
3. Resolution of required Treated Water Storage. The District will make a determination of whether the Applicant must dedicate treated water storage sufficient to serve the proposed development;
4. Agreements are in place for the construction or Major Facilities as identified during the application process; and
5. All requirements of the Construction Plan Approval process have been met to the satisfaction of the CRT.

A Construction Plan Approval Letter may include conditions to be met before Construction Acceptance, Final Acceptance or at other times as determined by the District. Construction Plan Approval Letters will expire after one year from the date of issuance if the Work has not commenced or has not been pursued diligently by the Applicant. Resubmission will be required before a new Construction Plan Approval Letter will be issued. Resubmitted plans must conform to Appendix C, Standard Specifications for Water Mains and Appendix D, Standard Specifications for Wastewater Mains in effect at the time of resubmission.

The District will not sign off on its referral of a Final Plat approval, or any similar approval process that approves specific density and land uses by a Land Use Authority, until a Construction Plan Approval Letter has been granted.

9.3 Initiation of Construction

Following the issuance of a Construction Plan Approval Letter by the District, the Applicant may proceed with construction. In addition to compliance with all construction requirements contained in these Rules and Regulations, the Applicant shall:

1. Submit one (1) set of the approved detailed construction and specifications plans for construction inspection purposes. The plans shall be stamped and signed by Applicant's design engineer. The District also requires submittal of an Electronic Drawing File (ACAD.DWG or ESRI Shapefile) of the approved plans. The District's intent for all surveys, plats, construction drawings, and record drawings is to bring them into our GIS(ESRI Software) and Asset Management System. All surveys, plats, construction drawings, and record drawings provided to the Eagle River Water and Sanitation District (ERWSD) or the Upper Eagle Regional Water Authority (UERWA) shall be tied to a horizontal coordinate system and a vertical datum. The horizontal coordinate system is NAD 1983 State Plane Colorado Central FIPS 0502 (US Feet). The vertical datum is North American Vertical Datum of 1988 (NAVD 88). Digital drawings like ACAD and GIS shall be scaled with a Ground to Grid Scaling Factor; and this Scaling Factor must be described in the approved detailed construction and specifications plans.
2. Schedule a mandatory preconstruction meeting at the construction site a minimum of five (5) business days after the plans have been submitted and accepted. Participants shall include but are not limited to the Applicant; Applicant's contractor, excavator and engineer; and the District representative. Construction may begin once the meeting has concluded, and the District Inspector has signed off. If a wastewater bypass is required, a wastewater bypass plan shall be submitted for approval by the District. See Section 9.3.4 for details.
3. Provide a complete Bill of Materials for all proposed water and wastewater infrastructure.
4. Secure and pay for all licenses and permits required for the Work.
5. Make adequate provisions for notification of customers, businesses and/or individuals who may be impacted (e.g., interruptions in service, traffic detours). The District shall be given two (2) business days' notice of any scheduled interruption of service and shall be notified immediately of any unscheduled interruptions of service. Work plans shall be designed to minimize interruptions. All affected customers, businesses and/or individuals shall be notified, in writing,

at least two (2) business days in advance of construction, and again upon any scheduled interruption of service.

6. Submit traffic control plans as approved by the appropriate governing agency.
7. The District encourages all Applicants to videotape any potential areas that may be affected by approved Water or Wastewater Main construction prior to construction so as to avoid potential conflicts that may arise during or after construction.
8. In the event that construction does not commence within twelve (12) months of the approval date, the plans must be resubmitted for review and approval. If construction on the main installation is halted for more than twelve (12) months, plans must be resubmitted for review and approval prior to commencement. Resubmitted plans must adhere to the most recently updated specifications.

9.3.1 Construction Site Safety Provisions

The safety of the public, Applicant's workers, District personnel and/or others who may be on the job site is the responsibility of the Applicant. At a minimum, safety requirements shall conform to the requirements of the Occupational Safety and Health Act (OSH Act). Failure to provide safe access to an excavation may result in rejection of the work if it cannot be safely inspected. Refer to Appendix C Standard Specifications for Water Mains and Appendix D, Standard Specifications for Wastewater Mains.

9.3.2 Inspection

All Work shall be inspected and approved by a District Inspector to ensure the Standard Specifications for Water and Wastewater Main Line Construction, the Construction Plan Approval Letter and the approved plans are complied with fully, including in regard to the quality of workmanship and materials. Any Work not accepted by the District Inspector shall be corrected to the Inspector's satisfaction. Problems that may require field judgment, in lieu of strict interpretation of the Standard Specifications for Water and Wastewater Main Line Construction, shall be resolved by the Applicant to the satisfaction of the District Inspector. Refer to Appendix C: Standard Specifications for Water Mains and Appendix D: Standard Specifications for Sewer Mains.

9.3.3 Field Maintenance Inspection Requirements

For all required Field Maintenance Inspections, refer to Appendix C: Standard Specifications for Water Mains and Appendix D: Standard Specifications for Wastewater Mains and Appendix E: Earthwork and Construction.

- a. High Chlorine Test – Water Main
- b. Low Chlorine Test – Water Main
- c. Bacteriological Test – Water Main
- d. Hydrostatic Pressure Test – Water Main

- e. Manhole Interior Inspection
 - f. Air Test – Wastewater Main
 - g. Main Jet Cleaned – Wastewater Main
 - h. Videotaping of Wastewater Main Extension
 - i. Trace Wire Testing-Water and Wastewater Mains
-
- 1. Valve Boxes/Curb Stops
 - a. All valve boxes shall be free of dirt, rocks, and debris. Valve box segments must be straight and plumb, centered over the operating nut, even with finished grade and operable. Refer to Appendix C Standard Specifications for Water Main Line Construction.
 - 2. Fire Hydrant
 - a. Fire hydrants shall be straight and plumb, have the specified clearances from obstructions, and be operable. Finished surface shall provide drainage away from the hydrant. Refer to Appendix C Standard Specifications for Water Main Line Construction for Fire Hydrant Assembly detail.
 - 3. Air/Vacuum Release Valves
 - a. All air/vacuum release valves shall be free of dirt, rocks, debris and at proper grade and operable. Refer to Appendix C Standard Specifications for Water Main Line Construction.
 - 4. Rough Grade Inspection
 - a. Above ground appurtenances are to be set at a reasonable grade so as not to allow standing water to accumulate on top of or allow drainage into or toward the appurtenances of the system. All appurtenances within the road right-of-way/ easement shall be protected from traffic, equipment, etc.

9.3.4 Bypass System Requirements

When Construction requires the shutdown of an existing Wastewater Main, a bypass system shall be required to ensure the uninterrupted operation of the Wastewater System. A bypass system can include the use of pumps with piping or hauling or gravity piping. The Contractor shall be responsible for submitting a Wastewater Flow Management Plan (WWFMP) to the District for review and approval a minimum of thirty (30) days prior to construction of the bypass. The Contractor shall always have a copy of the approved WWFMP on the construction site at all times and shall provide a copy to the District Inspector. See Appendix D for the WWFMP requirements.

The Contractor shall be responsible for protecting the bypass system throughout the duration of the Project and the Contractor shall be responsible for any damage caused

by their failure to provide adequate protection to the bypass system. A bypass system shall be attended at all times while operating.

The Contractor shall not cause or contribute to any incidence of overflows or spills of wastewater from the Wastewater System. To minimize the risk of an overflow or spill, the Contractor shall develop and submit to the District at least fifteen (15) working days prior to the start of construction at a site requiring flow management, a written Discharge Emergency Response Plan (DERP). See Appendix D DERP requirements.

9.4 Construction Acceptance

Construction Acceptance is the District's acceptance of completion of the Work. No Service Connections or use shall be made on the Water System or Wastewater System until a Construction Acceptance Letter has been issued by the District.

9.4.1 Construction Acceptance Submittal Requirements

Video Inspection

- a. Upon request by the Applicant for Construction Acceptance, the video inspection shall be provided to the District for review. The purpose of this inspection is to determine if the Main meets District standards and is free from defects, failure, debris and/or blockages. If the inspection reveals any defects, failures or debris, the Applicant shall correct, modify or remove the specific problem to the satisfaction of the District. Once necessary corrective actions have been completed, the Wastewater Main segment shall undergo another video inspection that shall be provided to the District prior to receiving Construction Acceptance.

Drawings of Record

- a. Drawings of Record shall be based on the approved Construction Plans and shall be clouded to clearly depict the accurate, scaled, field-verified location of the water and wastewater systems and appurtenances as constructed in the field and shall clearly delineate between existing and new water and wastewater infrastructure.
- b. Record drawings provided to the Eagle River Water and Sanitation District (ERWSD) or the Upper Eagle Regional Water Authority (UERWA) shall be tied to a horizontal coordinate system and a vertical datum. The horizontal coordinate system is NAD 1983 State Plane Colorado Central FIPS 0502 (US Feet). The vertical datum is North American Vertical Datum of 1988 (NAVD 88). Digital drawings like ACAD and GIS shall be scaled with a Ground to

ARTICLE 9 – INFRASTRUCTURE ACCEPTANCE PROCESS

Grid Scaling Factor; and this Scaling Factor must be described in the approved detailed construction and specifications plans.

- c. Drawings of record shall be submitted in ACAD.DWG or ESRI Shapefile), and PDF format on standard 24" x 36" plan sheets signed and stamped by the Applicant's Registered Professional Engineer or Land Surveyor and clearly labeled "Drawings of Record."
- d. The following are not considered Drawings of Record, and will not be accepted by the District:
 - i. Construction Plans
 - ii. Free hand drawings or sketches
 - iii. Drawing measurements that are based upon Main or Service locates that occurred after the Main or Service lines were backfilled.
- e. All drawings of record information shall be field surveyed under the direct care and supervision of a licensed Professional Land Surveyor. All adjacent rights-of-way, property boundaries, and easements shall be depicted based on field surveyed information and labeled with appropriate Eagle County recording information. Generally, drawings of record shall be submitted on a drawing scale of 1 inch = 20 feet; however, drawing scales up to 1 inch = 50 feet will be accepted for larger projects.

The Drawings of Record shall detail, at a minimum, the location of the following:

- 1. Water:
 - a. New water mains with diameter, length, material, insulation (if applicable), and ownership status (private or public) labeled.
 - b. New water service lines with tap location, diameter, length, material, and insulation (if applicable).
 - c. New fittings with type, diameter, material, and X, Y, Z state plane coordinates labeled.
 - d. New thrust blocks with size shown.
 - e. New fire hydrants with type, flange elevation, lateral invert elevation, extensions (if applicable), ownership status (private or public), and X, Y state plane coordinates labeled.
 - f. New valves, including curb stops, with sizes, type and X, Y, Z state plane coordinates labeled.
 - g. New vaults or other system appurtenances. Vault/manhole information, vault type, vault lid X, Y, Z state plane coordinates and extent of the below-grade structure.
 - h. Existing water mains and/ or services and abandoned mains or services shall be shown and labeled accordingly.

ARTICLE 9 – INFRASTRUCTURE ACCEPTANCE PROCESS

- i. Any other appropriate information shall also be included on the Drawings of Record to include insulation, cathodic protection, etc.
 - j. All utility crossings shall be labeled.
2. Wastewater:
- a. New wastewater mains with diameter, length, material, slope, secondary containment (if applicable), insulation (if applicable), and ownership status (private or public) labeled.
 - b. New wastewater service lines with tap location, diameter, material, length, insulation (if applicable), X, Y, Z state plane coordinates of stub out distal end and X, Y state planes coordinate of cleanouts labeled.
 - c. New manholes with diameter, type, invert elevations, rim elevations and X, Y state planes coordinates of the manhole lid labeled.
 - d. New fats, oil, and gas infrastructure labeled to include grease interceptor size, grease interceptor X,Y state plane coordinates, inspection pit rim elevations, inspection pit invert elevations, and service lines with diameter, length, material and cleanouts labeled.
 - e. All appurtenant details or shop drawings shall be included in the drawings of record. Other utility crossings, including storm water crossings, if applicable, shall be clearly depicted on the drawings.
 - f. All utility crossings shall be labeled.

Abandonment of existing Water and/or Wastewater System infrastructure shall be designated on the Drawings of Record as greyed out and shall be labeled as abandoned with the date of abandonment and pipe material. Details shall be included where abandoned Mains or Services are within a 20-foot radius of any Water System valves.

Upon submittal of the Drawings of Record, the Applicant's Registered Professional Engineer or Land Surveyor shall certify in writing that the Water and/or Wastewater Systems were constructed in accordance with the construction drawings and specifications approved by the District.

Easement Documents

The Applicant shall demonstrate that the Water and Wastewater System Infrastructure is located within exclusive easements. Easements recorded with the final plat of the development shall be provided, with specific recording information, on the Drawings of Record submission. If additional easements are required, the Applicant shall submit a completed District Water or Wastewater Easement Deed request form with the Drawings of Record submittal, along with an easement exhibit, stamped and signed by a registered professional land surveyor. Easement documentation shall demonstrate that the constructed Water or Wastewater Main has been field verified to be within and

generally centered in, the proposed or platted easement, and that the proposed easement meets the minimum requirements set forth in Appendix C Standard Specifications for Water Mains and Appendix D, Standard Specifications for Wastewater Mains.

Project Cost

A schedule of values to construct and/or install all Work shall be submitted. This shall include all engineering, labor, and material costs.

Bill of Sale

The District's standard Water or Wastewater Main Bill of Sale form shall be completed, notarized, and submitted to the District. An exhibit showing the Water or Wastewater Main shall be attached to the submittal. Refer to the document form in Appendix C Standard Specifications for Water Mains and/or Appendix D, Standard Specifications for Wastewater Mains.

Operations and Maintenance Manuals

Where applicable, the Applicant shall submit three (3) copies of the final hard cover bound Operation and Maintenance Manuals and one (1) electronic copy, incorporating any District review comments. Two (2) preliminary copies are to be submitted to the District for review and comments prior to equipment start up.

9.4.2 Warranty Period

The Applicant shall furnish to the District a warranty, secured by a surety bond if requested by the District, for a period of no less than two (2) years for the satisfactory repair or replacement, when required, or for the cost thereof, of all Work, material, services and equipment that may become defective as a result of faulty material(s) and/or equipment, faulty or improper installation, or improper handling of material(s) and/or equipment provided by the Applicant. For any main line extensions, the District reserves the right to, in its sole discretion, require Applicant to provide warranty and/or maintenance bonds or other appropriate security, in addition to the Applicant's warranty ensuring repair or replacement of the Work during the Warranty Period. Where defective Work (and damage to other Work resulting therefrom) has been corrected or removed and replaced within the warranty period, the correction period with respect to such Work will be extended for an additional period of two (2) years after such correction or removal and replacement has been satisfactorily completed.

The Warranty Period shall not start until Drawings of Record, recorded easement documents, project cost documents, and Bill of Sale, have been completed, and are received and approved by the District then Construction Acceptance may be granted.

During the Warranty Period, the District will test the integrity of any telemetry and/or cathodic protection systems installed by the Applicant. Any remedial repair and subsequent testing will be completed by the Applicant and inspected by the District.

Where defective work or materials have been found, the Applicant will be notified of the defect and subsequently have thirty (30) days to correct the defective work. After that time, the District will correct the defective work and the cost will be billed back to the Applicant.

9.4.3 Construction Acceptance Letter

The Construction Acceptance Letter grants the Applicant permission to apply for Connection to the District's Water and/or Wastewater System. No Service Connections shall be made prior to issuance of the letter. Once the letter has been issued, operation of the Water or Wastewater Main and related facilities will become the responsibility of the District; the Applicant or Applicant's Representative may not operate the Water or Wastewater Main or related facilities after Construction Acceptance. Construction Acceptance does not transfer ownership of the system to the District, or any liability.

The Construction Acceptance Letter will be issued once all required submissions have been approved by the Construction Review Team. The date of issuance of the letter is the start of the Warranty Period.

To apply for Connection, contact the District office:

Customer Service Department

846 Forest Road

Vail, CO 81657

(970) 477-5451

1. Water Service Line Connections
 - a. Once the Water Main has been constructed per the approved construction plans, Construction Acceptance has been granted by the District, and all applicable fees have been paid, the Applicant may connect to the Water System. Please refer to Appendix B.

9.5 Final Acceptance

Final Acceptance of the Work is the District's acceptance of ownership of the Work and inclusion of the Water or Wastewater Main into the District's system for service to Customers, system operations and maintenance and shall be the end of the Applicant's Warranty Period.

9.5.1 Final Acceptance Submittal Requirements

2. Final Grading and Paving Inspection

- a. The Applicant shall request a final grading and paving inspection by the District Inspector. The Water or Wastewater Main and any roadways, driveways, drainage and utilities that are a part of the Applicant's project shall be fully operational at the time of inspection. The District will complete final grade and paving inspection within ten (10) days of notification by the Applicant. The Applicant or Applicant Representative must be present during the inspection.

3. Video Inspection

- a. Upon request by the Applicant for Final Acceptance, the District will video the Wastewater Main at its cost. The purpose of this inspection is to determine if the Main continues to meet District standards and is free from defects, failure, debris and/or blockages. If the inspection reveals any defects, failures or debris, the Applicant shall correct, modify or remove the specific problem to the satisfaction of the District. The cost of this corrective action will be borne by the Applicant. Once necessary corrective actions have been completed, the District will video the Wastewater Main segment at the Applicant's expense.

4. Final Inspection

- a. After all construction is complete, including final grading and paving, and the warranty period has reached its 22nd month, a final inspection will be performed on the work.

9.5.2 Final Acceptance Letter

Upon Final Acceptance, the Warranty Period ends. A Final Acceptance Letter shall be issued when all warranty requirements are met and approved by the District.

The District will not sign off on its referral of the request to release a Subdivision Improvement Agreement bond, or any similar approval process by a Land Use Authority, until a Final Acceptance Letter has been granted.

ARTICLE 10 - WATER DEDICATION REQUIREMENT

10.1 General Purpose

The District is responsible for providing efficient, effective, and reliable water to its service area, manages the limited water resource, and plans for the needs of future water demands of redevelopment and new water uses within its service area. The District has established a uniform water dedication requirement that conditions water service upon either a dedication of water rights or a payment of cash in lieu of water rights sufficient to supply the proposed use. The water dedication requirement shall apply to:

1. All new development or redevelopment within the District's service area that will result in an increase in water use or a new water use not covered by existing taps or zoning that existed as of July 22, 2004, and;
2. All properties thereafter included within the Eagle River Water and Sanitation District or the service area of the Upper Eagle Regional Water Authority.

For redevelopment, the dedication requirement applies to the difference between the projected increased water demand and the pre-redevelopment water demand. The increase may be as a result of increased density, increased landscaping, or any other change in use of the property that increases the water demand from the pre-redevelopment demand.

10.2 Dedication of Water Rights

The dedication of water rights shall provide the District with a dependable legal supply of water equal to one hundred and twenty percent (120%) of the calculated new or increase in water demand associated with the new development or redevelopment. All water dedication agreements between Customers or Applicants and the District that provide water rights to the District shall be at the sole discretion of the District.

To the extent the District determines to accept a dedication of water rights, the following criteria shall be used in determining the type of water rights to be dedicated:

1. Shares of stock in the Eagle Park Reservoir Company representing the right to the annual release of water from Eagle Park and/or Homestake Reservoirs.
2. Water rights that could be used to enhance the yield of Eagle Park Reservoir.
3. Interests in consumptive use credits that are already decreed for diversion and use at the District's diversion points.
4. Imported/trans-basin water that is available for use in the Colorado River basin upstream of the Shoshone Power Plant.

ARTICLE 10 – WATER DEDICATION REQUIREMENT

5. Other water rights or storage facilities that can be integrated into the District's water system or used to enhance existing exchanges without significant expense.
6. All dedicated water rights must be owned in fee and cannot be based on a term limited leasehold interest.

10.3 Cash In Lieu of Water Rights

Approval of cash payment in lieu of the dedication of water rights shall be at the sole discretion of the District and shall be subject to the following conditions:

1. The District has sufficient unallocated water rights in its portfolios to meet the new water service obligation.
2. The Customer or Applicant does not have access to the type of water rights that meet the District's criteria for acceptance of water rights.
3. Any historical water rights appurtenant to the land to be served have been previously severed.
4. Cash payments based on 120% of the calculated new or increase in water use shall not be less than the current Water Rights Dedication Cash in Lieu Fee. Refer to Appendix A, Monthly Water Service Charges and Rates.
5. Cash payments shall be paid to the District to be used, at the discretion of the District, to develop and/or acquire additional in-basin storage or imported/trans-basin water for the District.

10.4 Payment of Costs

All payment of costs regarding water dedication agreements between Customers or Applicants and the District shall be subject to the following conditions:

1. Customers or Applicants shall be required to pay the District for all legal, engineering, and other costs incurred or which may be incurred by the District to evaluate and/or adjudicate any augmentation plan or other water court application, if necessary, to provide new or increased water service to any Customer's or Applicant's property.
2. An engineering or legal evaluation is required by the District to evaluate the terms of the water dedication requirement. The Customer or Applicant will be required to deposit with the District an initial deposit to reimburse the cost of such evaluation. The initial deposit shall be used to pay the costs of staff, legal consultants, engineering consultants, and other expenses that may be incurred by the District. These costs are separate and distinct from any other Impact Fees and other charges applicable to the development. This cost reimbursement is not related or credited to any other fee of the District. Deposit amounts in excess of

the actual cost of the analysis will be refunded to the Customer or Applicant for the development. A good faith effort will be made to generally account for the costs incurred, but the District shall not be obligated to provide a specific accounting of costs, but only a generalized estimate. Refer to Appendix A, Schedule of Fees and Rates.

3. In the event water service is no longer required or desired, any refund of a cash in lieu payment previously paid shall be at the sole discretion of the District. Where the District decides in its sole discretion to refund a cash in lieu payment, the District may charge a cancellation fee. The District will not refund a cash in lieu payment once the property to which water service has been extended has obtained land use approval unless such land use approval is revoked or otherwise terminated by the relevant Land Use Authority.

10.5 Applicability of Requirement

Upon receiving a referral from the Land Use Authority for an ability to serve commitment, the District staff shall determine whether this requirement is applicable to any property that is currently within the District's service area and that is being developed or redeveloped.

10.6 Consideration of Prior Dedications

In determining the amount of any water rights dedication or cash payment in lieu, thereof, consideration shall be given to any past dedications of water rights by the Customer or Applicant and whether excess water rights exist from such past dedications.

ARTICLE 11 - WATER SUPPLY RESPONSE PLAN

11.1 Goals

This Water Supply Response Plan outlines guidelines the Eagle River Water and Sanitation District and Upper Eagle Regional Water Authority will use to manage the water supply and water use during times of actual or anticipated water shortages. The primary goals of this Water Supply Response Plan are to maximize the available water supply, reduce water use, and optimize stream flows when necessary to preserve reservoir storage, protect stream health, and protect public health and safety.

11.2 Water Supply Emergencies

Various conditions which may result in the declaration of a water supply emergency and implementation of emergency water use restrictions are set forth in Article 6, Use Restrictions – Water Supply Emergencies, and include low river flows, impairment of water supply quantity and/or quality, and serious operational challenges.

11.3 Response Levels

If the General Manager determines a declaration of a Water Supply Emergency is appropriate, the General Manager may implement one of the following response levels depending on the severity of the situation. Applicable factors may include snowpack, precipitation, temperature, wind, predicted reservoir storage, evaporation, streamflow, soil moisture, and weather forecasts. Regardless of the water supply situation, staff routinely monitors hydrologic conditions, and this monitoring intensifies during dry periods. Additional considerations in determining the appropriate response level include maintaining the health, safety, and economic vitality of the community; minimizing adverse impacts to public activity and quality of life for the community; and considering reasonable individual customer needs.

The Eagle River Water and Sanitation District and Upper Eagle Regional Water Authority recognize that many local governments and commercial entities in the area rely on outdoor use of water for economic benefits and recreational purposes, and water restrictions imposed in response to water shortages can affect businesses in different ways. As part of their public outreach efforts during a Water Supply Emergency, the Eagle River Water and Sanitation District and Upper Eagle Regional Water Authority will continue to carefully coordinate restriction programs to consider impacts on customers. If conditions change after a Water Supply Emergency has been declared, the General Manager may lift or adjust the level of response.

11.4 Dry Year Response

The goal of a Dry Year Response is to forestall an instream flow call and preserve reservoir storage. During such a Response, the Eagle River Water and Sanitation District and Upper Eagle Regional Water Authority will work to obtain a voluntary reduction in water use by all customers. The normal Water Use Regulations will be enforced. Additionally, enforcement will focus on eliminating unsustainable water use by customers using water in billing tiers 4 and 5.

Dry Year Response Restrictions

During this Response, the following restrictions on water use will be implemented:

1. Water usage will be limited to use in Tier 3 or less.

Violations

Any customer who violates Dry Year Response Restrictions will be subject to penalties associated with violations of the normal Water Use Regulations, in addition to any other fees, fines, or penalties authorized by these Rules and Regulations:

- | | |
|------------------------------|------------------------------------|
| 1st Offense: | Warning letter and/or email |
| 2nd Offense: | \$100 fine, letter, and phone call |
| 3rd and Subsequent Offenses: | \$500 fine and letter |

11.5 Resource Protection Response

The goal of a Resource Protection Response is to forestall an instream flow call and preserve stream health. During such a Response, the Eagle River Water & Sanitation District and Upper Eagle Regional Water Authority will enforce mandatory reductions in water use. Enforcement will focus on eliminating excessive or unsustainable water use by customers using water in billing tiers 3, 4, and 5.

Resource Protection Response Restrictions

During this Response, the following restrictions on water use will be implemented:

1. Water usage will be limited to use in Tier 2 or less.

Violations

Any customer who violates Resource Protection Response restrictions will be subject to the following penalties, in addition to any other fees, fines, or penalties authorized by these Rules and Regulations:

1st Offense: Warning letter and/or email

2nd Offense: \$500 fine, letter, and Notice of Potential Disconnection

3rd Offense: \$500 fine, \$100 disconnection of water service fee, and disconnection of water service line.

11.6 Public Health and Safety Response

The goal of a Public Health and Safety Response is to protect the aquatic environment from water diversions and ensure, to the extent possible, that there is adequate water for essential indoor and public safety/fire protection uses. During such a Response, the Eagle River Water & Sanitation District and Upper Eagle Regional Water Authority will prohibit all outdoor water use and limit indoor water use to essential uses.

Public Health and Safety Response Restrictions

During this Response, the following restrictions on water use will be implemented:

1. Outdoor water use is prohibited unless the Board of Directors authorizes exceptions.
2. Indoor water use will be limited to use in Tier 1 only.

Violations

Any customer who violates the Public Health and Safety Response restrictions will be subject to the following penalties, in addition to any other fees, fines, or penalties authorized by these Rules and Regulations:

1st Offense: \$500 fine and Notice of Potential Disconnection

2nd Offense: \$500 fine, \$100 disconnection of water service fee, and disconnection of water service line.

For reinstatement of service refer to section 1.11.